

12/20/89 10:11:50

GRAPHIC SYSTEM DISPLAY


Wednesday December 20, 1989

SYSTEM

PPET BMET MIDET

WELL PUMPS

- 643
- 644
- 646
- 647
- 648
- 649
- 650
- 698
- 699
- 700
- 701
- 703
- 704
- 705
- 706
- 707
- 708



ALL FLOWS IN MGD  
ALL LEVELS IN FEET

WATER SYSTEM BLDG.670

Print Cnst Print Scrn Rep Const **Select** Test

< ESC > =====>

1

1

Wednesday December 20, 1989

```

1) Point Id           : TMPC
2) Description        : TRANS MAIN PUMP CONTROL
3) Mult. Step Control : Enable
4) Control Direction : Falling
5) Num Control Levels : 1 (0 Disables Control)
   Control Level      Point Id      Current Value
   1                  6) TTRESLVL   7) 11.5
   2                  8)             9) 0
   3                  10)            11) 0

```

```

12) Number Of Steps : 2

```

Step	ON	Setpoint	OFF	Setpoint	Time Delay	Timer	Step Status
1	13)	10.9	14)	11.5	15)	20	16) 0 17) On
2	18)	9.8	19)	10.8	20)	20	21) 0 22) Off
3	23)	0.0	24)	0.0	25)	0	26) 0 27) Off
4	28)	0.0	29)	0.0	30)	0	31) 0 32) Off
5	31)	0.0	34)	0.0	35)	0	36) 0 37) Off
6	38)	0.0	39)	0.0	40)	0	41) 0 42) Off

```

Step ----- Pump Control Assignments -----


```

1	43) TMP1	44)	45)	46)	47)
	48)	49)	50)	51)	52)
2	53)	54) TMP2	55)	56)	57)
	58)	59)	60)	61)	62)
3	63)	64)	65)	66)	67)
	68)	69)	70)	71)	72)
4	73)	74)	75)	76)	77)
	78)	79)	80)	81)	82)
5	83)	84)	85)	86)	87)
	88)	89)	90)	91)	92)
6	93)	94)	95)	96)	97)
	98)	99)	100)	101)	102)

```

103) Alternate Option : Yes
      Pump Id      alternate with      Pump Id
      104) TMP1    105) TMP2
      106)         107)

```



Wednesday December 20, 1989

1) Point Id : TTPC  
 2) Description : TARAWA PUMP STATION  
 3) Mult. Step Control : Enable  
 4) Control Direction : Falling  
 5) Num Control Levels : 1 (0 Disables Control)

Control Level	Point Id	Current Value
1	6) TTETLVL	7) 26.0
2	8)	9) 0
3	10)	11) 0

12) Number Of Steps : 4


Step	ON Setpoint	OFF Setpoint	Time Delay	Timer	Step Status
1	13) 26.0	14) 27.0	15) 30	16)	0 17) On
2	18) 25.2	19) 26.0	20) 30	21)	0 22) Off
3	23) 23.0	24) 25.0	25) 30	26)	0 27) Off
4	28) 21.0	29) 23.0	30) 30	31)	0 32) Off
5	31) 0.0	34) 0.0	35) 0	36)	0 37) Off
6	38) 0.0	39) 0.0	40) 0	41)	0 42) Off

Step ----- Pump Control Assignments -----

1	43) TTP1	44)	45)	46)	47)
	48)	49)	50)	51)	52)
2	53) TTP2	54)	55)	56)	57)
	58)	59)	60)	61)	62)
3	63) TTP3	64)	65)	66)	67)
	68)	69)	70)	71)	72)
4	73) TTP4	74)	75)	76)	77)
	78)	79)	80)	81)	82)
5	83)	84)	85)	86)	87)
	88)	89)	90)	91)	92)
6	93)	94)	95)	96)	97)
	98)	99)	100)	101)	102)

103) Alternate Option : Yes

Pump Id	alternate with	Pump Id
104) TTP1	105) TTP3	
106)	107)	



Wednesday December 20, 1989

- 1) Point Id : RWPC
  - 2) Description : RAW WATER PUMP CONTROL
  - 3) Mult. Step Control : Enable
  - 4) Control Direction : Falling
  - 5) NUM Control Levels : 1 (0 Disables Control)
- |               |            |               |
|---------------|------------|---------------|
| Control Level | Point Id   | Current Value |
| 1             | 6) HBFWRL  | 7) 8.0        |
| 2             | 8) TRMWRSV | 9) 12.2       |
| 3             | 10)        | 11) 0         |


12) Number Of Steps : 1

Step	ON Setpoint	OFF Setpoint	Time Delay	Timer	Step Status
1	13) 8.3	14) 9.2	15) 20	16) 0	17) On
2	18) 7.9	19) 8.3	20) 20	21) 0	22) Off
3	23) 7.5	24) 7.9	25) 20	26) 0	27) Off
4	28) 7.0	29) 7.5	30) 20	31) 0	32) Off
5	31) 0.0	34) 0.0	35) 0	36) 0	37) Off
6	38) 0.0	39) 0.0	40) 0	41) 0	42) Off

Step	Pump Control Assignments							
1	43)	44) LSU4	45) RWP1	46) LSU1	47) RWP4			
	48) LSU3	49) LSU2	50) LSU5	51)	52)			
2	53)	54)	55)	56)	57)			
	58)	59)	60)	61)	62)			
3	63)	64)	65)	66)	67)			
	68)	69)	70)	71)	72)			
4	73)	74)	75)	76)	77)			
	78)	79)	80)	81)	82)			
5	83)	84)	85)	86)	87)			
	88)	89)	90)	91)	92)			
6	93)	94)	95)	96)	97)			
	98)	99)	100)	101)	102)			

103) Alternate Option : Yes

Pump Id	alternate with	Pump Id
104) RWP1	105) RWP2	
106)	107)	



Wednesday December 20, 1989

- 1) Point Id : WPC
- 2) Description : WELL PUMP CONTROL
- 3) Mult. Step Control : Enable
- 4) Control Direction : Falling
- 5) Num Control Levels : 1 (0 Disables Control)

Control Level	Point Id	Current Value
1	6) RWTRESV	7) 15.5
2	8)	9) 0
3	10)	11) 0

12) Number Of Steps : 2

Step	ON Setpoint	OFF Setpoint	Time Delay	Timer	Step Status
1	13) 15.5	14) 16.2	15) 20	16)	0 17) On
2	18) 15.5	19) 16.2	20) 120	21)	0 22) On
3	23) 0.0	24) 0.0	25) 0	26)	0 27) Off
4	28) 0.0	29) 0.0	30) 0	31)	0 32) Off
5	31) 0.0	34) 0.0	35) 0	36)	0 37) Off
6	38) 0.0	39) 0.0	40) 0	41)	0 42) Off

Step	Pump Control Assignments									
1	43) WP698	44) WP699	45) WP700	46) WP701	47) WP703					
	48) WP704	49) CBP1	50) WP706	51) WP707	52) WP708					
2	53) WP705	54) WP647	55) WP648	56) WP649	57) WP643					
	58) WP646	59)	60) WP650	61)	62)					
3	63)	64)	65)	66)	67)					
	68)	69)	70)	71)	72)					
4	73)	74)	75)	76)	77)					
	78)	79)	80)	81)	82)					
5	83)	84)	85)	86)	87)					
	88)	89)	90)	91)	92)					
6	93)	94)	95)	96)	97)					
	98)	99)	100)	101)	102)					

103) Alternate Option : No Pump Id alternate with Pump Id  
 104) 105)  
 106) 107)



12/20/89 10:03:55

**Base Level Control Point**

Page 2 of

Wednesday December 20, 1989

- 1) Point Id : HBPC
  - 2) Description : HOLCMB BLVD PUMP CONTROL
  - 3) Mult. Step Control : Disable
  - 4) Control Direction : Falling
  - 5) Num Control Levels : 1 (0 Disables Control)
- |               |            |               |
|---------------|------------|---------------|
| Control Level | Point Id   | Current Value |
| 1             | 6) PPETLVL | 7) 26.5       |
| 2             | 8)         | 9) 0          |
| 3             | 10)        | 11) 0         |


12) Number Of Steps : 3

Step	ON Setpoint	OFF Setpoint	Time Delay	Timer	Step Status
1	13) 28.0	14) 30.0	15) 20	16)	0 17) On
2	18) 26.0	19) 28.0	20) 20	21)	0 22) Off
3	23) 25.5	24) 26.0	25) 20	26)	0 27) Off
4	28) 0.0	29) 0.0	30) 20	31)	0 32) Off
5	31) 0.0	34) 0.0	35) 0	36)	0 37) Off
6	38) 0.0	39) 0.0	40) 0	41)	0 42) Off

Step	Pump Control Assignments					
1	43) HBP2	44)	45)	46)	47)	
	48)	49)	50)	51)	52)	
2	53) HBP1	54) HBP2	55)	56)	57)	
	58)	59)	60)	61)	62)	
3	63) HBP2	64) HBP3	65)	66)	67)	
	68)	69)	70)	71)	72)	
4	73)	74)	75)	76)	77)	
	78)	79)	80)	81)	82)	
5	83)	84)	85)	86)	87)	
	88)	89)	90)	91)	92)	
6	93)	94)	95)	96)	97)	
	98)	99)	100)	101)	102)	

103) Alternate Option : Yes

Pump Id	alternate with	Pump Id
104) HBP1	105) HBP2	
106)	107)	



12/19/89 15:09:15


**RUN TIME DISPLAY**

Page 39 of 101

Tuesday December 19, 1989

	DAILY	WEEKLY	MONTHLY	FLows DAILY
WP698	9.30	41.48	295.92	RAW WATER 1567.293
WP699	9.32	41.48	295.84	PLANT INF 1452.446
WP700	9.32	41.48	294.61	HOLCOMB 721.471
WP701	9.32	41.49	295.22	TRANSMISSION 635.750
WP703	0.00	0.00	158.85	
WP704	9.35	41.52	295.89	
WP705	9.22	41.28	293.99	
WP706	0.00	0.00	158.50	
WP707	0.00	0.00	158.89	
WP708	0.00	0.00	158.97	
WP643	9.23	41.22	136.19	
WP644	0.00	0.00	0.00	
OBP1	5.58	5.58	255.53	
WP646	9.22	41.20	294.06	
WP647	9.22	41.20	293.10	
WP648	9.25	41.22	136.20	
WP649	9.25	41.29	136.18	
WP650	9.26	41.11	294.02	
RWP1	8.57	24.77	143.19	
RWP2	1.43	18.01	161.84	
RWP3	0.00	0.00	0.23	
RWP4	0.00	0.00	0.00	
HBP1	9.97	36.62	214.99	
HBP2	1.84	13.61	207.54	
HBP3	1.36	4.81	25.79	
HBP4	0.00	0.00	0.00	
HBP5	0.00	0.00	0.00	
TMP1	2.73	12.00	85.76	
TMP2	3.00	12.33	91.20	
TMP3	0.00	0.00	0.00	
BW2	0.00	0.00	0.00	
BW1	1.42	2.92	8.87	
LSU001	0.00	0.00	108.81	
LSU002	10.01	42.78	196.36	
LSU003	10.01	42.78	305.09	
LSU004	0.00	0.00	66.83	
LSU005	10.01	42.78	238.26	

Print Cnst Print Scrn Rep Const **Select** Test < ESC > =====>




12/19/89 02:28:15

**HB PIPE PRINT**


Page 245 of 181

Tuesday December 19, 1989

- RAW \_\_\_\_\_
- TREATED \_\_\_\_\_
- DELIVER \_\_\_\_\_
- BACKWASH \_\_\_\_\_
- BYPASS \_\_\_\_\_



HBRESLVL B20 POOLS **HB PIPE** TT Spare =====>



# Memorandum

5000  
MAIN

DATE: 1 February 1988

FROM: Water Treatment Plant Operator Foreman

TO: Leaders, Operators of Bldg. 670, 20, AS-110

SUBJ: SAMPLING PROCEDURE - FLUORIDE

1. The State of North Carolina required a fluoride sample be taken from the distribution system of each water plant. The rules governing Public Water Supplies Section: 0606, par. (c) state this. To insure proper sampling procedures, we must increase our sampling of fluoride. The following procedures will be implemented immediately:


a. Bldg. 670 - The operator will pick up samples from TT-38 or Camp Johnson pool daily on his check and bring back to 670 for the fluoride analysis to be run and recorded on log sheet under fluoride sample for distribution system.

b. Bldg. 20 - The well person will pick up sample from Bldg. 540 or 236 daily. Well person will carry sample to Bldg. 20 for operator to run fluoride analysis and record on log sheet under fluoride sample for distribution system.

c. Bldg. AS-110 - The well person will pick up sample from Bldg. TC-501 daily. Well person will carry sample to AS-110 for operator to run fluoride analysis and record on log sheet under fluoride sample for distribution system.

2. Your cooperation will be greatly appreciated in this increase sampling procedure.

  
STANLEY L. MILLER



*Memorandum*

5000  
MAIN


**DATE:** 23 January 1989

**FROM:** Water Treatment Plant Operator Foreman


**TO:** All Leaders and Operators

**SUBJ:** VEHICLE HOURLY USAGE RECORD

1. To maintain a more accurate record of time vehicle is used, the following method is recommended. When the daily report is called in from Courthouse Bay and Air Station, ask for hours vehicle has been used during the 24 hour period. Each operator of vehicle should make note of hours vehicle has been used each shift, including 670 well and supply persons.




STANLEY L. MILLER



## CENTIGRADE CONVERSION TO FAHRENHEIT

°C	°F
40	104
39	102.2
38	100.4
37	98.6
36	96.8
35	95
34	93.2
33	91.4
32	89.6
31	87.8
30	86
29	84.2
28	84.2
27	80.6
26	78.8
25	77
24	75.2
23	73.4
22	71.6
21	69.8
20	68
19	66.2
18	64.4
17	63.6
16	60.8
15	59
14	57.2
13	55.4
12	53.6
11	51.8
10	50
9	48.2
8	46.4
7	44.6
6	42.8
5	41
4	39.2
3	37.4
2	35.6
1	33.8
0	32
-1	30.2
-2	28.4
-3	26.8
-4	24.8
-5	23
-6	21.2
-7	19.4
-8	17.6
-9	15.8
-10	14



# Temperature Conversion

-459.4 to 0			1 to 60			61 to 290			300 to 890			900 to 3000		
C	C	F	C	C	F	C	C	F	C	C	F	C	C	F
	F		F	F		F	F		F	F		F	F	
-273	-459.4		-17.2	1	33.8	16.1	61	141.8	149	300	572	482	900	1652
-268	-450		-16.7	2	35.6	16.7	62	143.6	154	310	590	488	910	1670
-262	-440		-16.1	3	37.4	17.2	63	145.4	160	320	608	493	920	1688
-257	-430		-15.6	4	39.2	17.8	64	147.2	166	330	626	499	930	1706
-251	-420		-15.0	5	41.0	18.3	65	149.0	171	340	644	504	940	1724
-246	-410		-14.4	6	42.8	18.9	66	150.8	177	350	662	510	950	1742
-240	-400		-13.9	7	44.6	19.4	67	152.6	182	360	680	516	960	1760
-234	-390		-13.3	8	46.4	20.0	68	154.4	188	370	698	521	970	1778
-229	-380		-12.8	9	48.2	20.6	69	156.2	193	380	716	527	980	1796
-223	-370		-12.2	10	50.0	21.1	70	158.0	199	390	734	532	990	1814
-218	-360		-11.7	11	51.8	21.7	71	159.8	204	400	752	538	1000	1832
-212	-350		-11.1	12	53.6	22.2	72	161.6	210	410	770	549	1020	1868
-207	-340		-10.6	13	55.4	22.8	73	163.4	216	420	788	560	1040	1904
-201	-330		-10.0	14	57.2	23.3	74	165.2	221	430	806	571	1060	1940
-196	-320		-9.4	15	59.0	23.9	75	167.0	227	440	824	582	1080	1976
-190	-310		-8.9	16	60.8	24.4	76	168.8	232	450	842	593	1100	2012
-184	-300		-8.3	17	62.6	25.0	77	170.6	238	460	860	604	1120	2048
-179	-290		-7.8	18	64.4	25.6	78	172.4	243	470	878	616	1140	2084
-173	-280		-7.2	19	66.2	26.1	79	174.2	249	480	896	627	1160	2120
-169	-273	-459.4	-6.7	20	68.0	26.7	80	176.0	254	490	914	638	1180	2156
-163	-270	-454	-6.1	21	69.8	27.2	81	177.8	260	500	932	649	1200	2192
-162	-260	-436	-5.6	22	71.6	27.8	82	179.6	266	510	950	660	1220	2228
-157	-250	-418	-5.0	23	73.4	28.3	83	181.4	271	520	968	671	1240	2264
-151	-240	-400	-4.4	24	75.2	28.9	84	183.2	277	530	986	682	1260	2300
-146	-230	-382	-3.9	25	77.0	29.4	85	185.0	282	540	1004	693	1280	2336
-140	-220	-364	-3.3	26	78.8	30.0	86	186.8	288	550	1022	704	1300	2372
-134	-210	-346	-2.8	27	80.6	30.6	87	188.6	293	560	1040	732	1350	2462
-129	-200	-328	-2.2	28	82.4	31.1	88	190.4	299	570	1058	760	1400	2552
-123	-190	-310	-1.7	29	84.2	31.7	89	192.2	304	580	1076	788	1450	2642
-118	-180	-292	-1.1	30	86.0	32.2	90	194.0	310	590	1094	816	1500	2732
-112	-170	-274	-.6	31	87.8	32.8	91	195.8	316	600	1112	843	1550	2822
-107	-160	-256	0	32	89.6	33.3	92	197.6	321	610	1130	871	1600	2912
-101	-150	-238	.6	33	91.4	33.9	93	199.4	327	620	1148	899	1650	3002
-96	-140	-220	1.1	34	93.2	34.4	94	201.2	332	630	1166	927	1700	3092
-90	-130	-202	1.7	35	95.0	35.0	95	203.0	338	640	1184	954	1750	3182
-84	-120	-184	2.2	36	96.8	35.6	96	204.8	343	650	1202	982	1800	3272
-79	-110	-166	2.8	37	98.6	36.1	97	206.6	349	660	1220	1010	1850	3362
-73	-100	-148	3.3	38	100.4	36.7	98	208.4	354	670	1238	1038	1900	3452
-68	-90	-130	3.9	39	102.2	37.2	99	210.2	360	680	1256	1066	1950	3542
-62	-80	-112	4.4	40	104.0	37.8	100	212.0	366	690	1274	1093	2000	3632
-57	-70	-94	5.0	41	105.8	43	110	230	371	700	1292	1121	2050	3722
-51	-60	-76	5.6	42	107.6	49	120	248	377	710	1310	1149	2100	3812
-46	-50	-58	6.1	43	109.4	54	130	266	382	720	1328	1177	2150	3902
-40	-40	-40	6.7	44	111.2	60	140	284	388	730	1346	1204	2200	3992
-34	-30	-22	7.2	45	113.0	66	150	302	393	740	1364	1232	2250	4082
-29	-20	-4	7.8	46	114.8	71	160	320	399	750	1382	1260	2300	4172
-23	-10	14	8.3	47	116.6	77	170	338	404	760	1400	1288	2350	4262
-17.8	0	32	8.9	48	118.4	82	180	356	410	770	1418	1316	2400	4352
			9.4	49	120.2	88	190	374	416	780	1436	1343	2450	4442
			10.0	50	122.0	93	200	392	421	790	1454	1371	2500	4532
			10.6	51	123.8	99	210	410	427	800	1472	1399	2550	4622
			11.1	52	125.6	100	212	413.6	432	810	1490	1427	2600	4712
			11.7	53	127.4	104	220	428	438	820	1508	1454	2650	4802
			12.2	54	129.2	110	230	446	443	830	1526	1482	2700	4892
			12.8	55	131.0	116	240	464	449	840	1544	1510	2750	4982
			13.3	56	132.8	121	250	482	454	850	1562	1538	2800	5072
			13.9	57	134.6	127	260	500	460	860	1580	1566	2850	5162
			14.4	58	136.4	132	270	518	466	870	1598	1593	2900	5252
			15.0	59	138.2	138	280	536	471	880	1616	1621	2950	5342
			15.6	60	140.0	143	290	554	477	890	1634	1649	3000	5432

Locate temperature in middle column. If in degrees Centigrade, read Fahrenheit equivalent in right hand column; if in degrees Fahrenheit, read Centigrade equivalent in left hand column.


Abstracted from "Bethlehem Alloy Steels". (Albert Sauveur type of table. Values revised.) Courtesy Bethlehem Steel Company.



160  
200  
112000

<u>JON</u>	<u>DESCRIPTION</u>	<u>WGC</u>	<u>CAC</u>	<u>SFC</u>
	<u>M&amp;R TO WATER SUPPLY &amp; TREATMENT FACILITIES &amp; EQUIPMENT</u>			
23-A243-2372-T 2373-T 2383-T	Building BA-138	01	7650	M1
AM_-23-A244-2372-T 2373-T 2383-T	Building BA-138	02	7650	M1
AM_-23-A245-2372-T 2373-T 2383-T	Building 670	01	7650	M1
AM_-23-A246-2372-T 2373-T 2383-T	Building 670	02	7650	M1
AM_-23-A247-2372-T 2373-T 2383-T	Building AS-110	01	7650	M1
AM_-23-A248-2372-T 2373-T 2383-T	Building AS-110	02	7650	M1
	<u>M&amp;R TO SEWAGE TREATMENT FACILITIES. Equipment Only</u>			
AM_-23-A249-2372-T 2373-T 2384-T	Building 22	01	7670	M1
AM_-23-A250-2372-T 2373-T 2384-T	Building 22	02	7670	M1
AM_-23-A251-2372-T 2373-T 2384-T	Building TC-563	01	7670	M1
AM_-23-A252-2372-T 2373-T 2384-T	Building TC-563	02	7670	M1
AM_-23-A253-2372-T 2373-T 2384-T	Building M-136 M-137 M-138	01	7670	M1

for MCAS Pools



JON

DESCRIPTION

WGWC

CAC

SFC

M&R TO PLANTS OVER 3.5  
MILLION BTU. Equipment Only

AM\_-23-A232-2372-T  
2373-T  
2381-T

Building AS-4151

02

7620

M1

01 - 3 DAYS  
02 - 14 DAYS

M&R TO WATER SUPPLY &  
TREATMENT FACILITIES  
& EQUIPMENT

AM\_-23-A233-2372-T  
2373-T  
2383-T

Building 20

01

7650

M1

AM\_-23-A234-2372-T  
2373-T  
2383-T

Building 20

02

7650

M1

AM\_-23-A235-2372-T  
2373-T  
2383-T

Building TT-38

01

7650

M1

AM\_-23-A236-2372-T  
2373-T  
2383-T

Building TT-38

02

7650

M1

AM\_-23-A237-2372-T  
2373-T  
2383-T

Building M-178

01

7650

M1

AM\_-23-A238-2372-T  
2373-T  
2383-T

Building M-178

02

7650

M1

AM\_-23-A239-2372-T  
2373-T  
2383-T

Building RR-85

01

7650

M1

AM\_-23-A240-2372-T  
2373-T  
2383-T

Building RR-85

02

7650

M1

AM\_-23-A241-2372-T  
2373-T  
2383-T

Building BB-190

01

7650

M1


AM\_-23-A242-2372-T  
2373-T  
2383-T

Building BB-190

02

7650

M1



# Power Required for Pumping

Gals. per Min.	Theoretical Horsepower Required to Raise Water (at 60 F) To Different Heights														
	5 feet	10 feet	15 feet	20 feet	25 feet	30 feet	35 feet	40 feet	45 feet	50 feet	60 feet	70 feet	80 feet	90 feet	100 feet
5	0.006	0.013	0.019	0.025	0.032	0.038	0.044	0.051	0.057	0.063	0.076	0.088	0.101	0.114	0.126
10	0.013	0.025	0.038	0.051	0.063	0.076	0.088	0.101	0.114	0.126	0.152	0.177	0.202	0.227	0.253
15	0.019	0.038	0.057	0.076	0.095	0.114	0.133	0.152	0.171	0.190	0.227	0.265	0.303	0.341	0.379
20	0.025	0.051	0.076	0.101	0.126	0.152	0.177	0.202	0.227	0.253	0.303	0.354	0.404	0.455	0.505
25	0.032	0.063	0.095	0.126	0.158	0.190	0.221	0.253	0.284	0.316	0.379	0.442	0.505	0.568	0.632
30	0.038	0.076	0.114	0.152	0.190	0.227	0.265	0.303	0.341	0.379	0.455	0.531	0.606	0.682	0.758
35	0.044	0.088	0.133	0.177	0.221	0.265	0.310	0.354	0.398	0.442	0.531	0.619	0.707	0.796	0.884
40	0.051	0.101	0.152	0.202	0.253	0.303	0.354	0.404	0.455	0.505	0.606	0.707	0.808	0.910	1.011
45	0.057	0.114	0.171	0.227	0.284	0.341	0.398	0.455	0.512	0.568	0.682	0.796	0.910	1.023	1.137
50	0.063	0.126	0.190	0.253	0.316	0.379	0.442	0.505	0.568	0.632	0.758	0.884	1.011	1.137	1.263
60	0.076	0.152	0.227	0.303	0.379	0.455	0.531	0.606	0.682	0.758	0.910	1.061	1.213	1.364	1.516
70	0.088	0.177	0.265	0.354	0.442	0.531	0.619	0.707	0.796	0.884	1.061	1.238	1.415	1.592	1.768
80	0.101	0.202	0.303	0.404	0.505	0.606	0.707	0.808	0.910	1.011	1.213	1.415	1.617	1.819	2.021
90	0.114	0.227	0.341	0.455	0.568	0.682	0.796	0.910	1.023	1.137	1.364	1.592	1.819	2.046	2.274
100	0.126	0.253	0.379	0.505	0.632	0.758	0.884	1.011	1.137	1.263	1.516	1.768	2.021	2.274	2.526
125	0.158	0.316	0.474	0.632	0.790	0.947	1.105	1.263	1.421	1.579	1.895	2.211	2.526	2.842	3.158
150	0.190	0.379	0.568	0.758	0.947	1.137	1.326	1.516	1.705	1.895	2.274	2.653	3.032	3.411	3.790
175	0.221	0.442	0.663	0.884	1.105	1.326	1.547	1.768	1.990	2.211	2.653	3.095	3.537	3.979	4.421
200	0.253	0.505	0.758	1.011	1.263	1.516	1.768	2.021	2.274	2.526	3.032	3.537	4.042	4.548	5.053
250	0.316	0.632	0.947	1.263	1.579	1.895	2.211	2.526	2.842	3.158	3.790	4.421	5.053	5.684	6.316
300	0.379	0.758	1.137	1.516	1.895	2.274	2.653	3.032	3.411	3.790	4.548	5.305	6.063	6.821	7.579
350	0.442	0.884	1.326	1.768	2.211	2.653	3.095	3.537	3.979	4.421	5.305	6.190	7.074	7.958	8.842
400	0.505	1.011	1.516	2.021	2.526	3.032	3.537	4.042	4.548	5.053	6.063	7.074	8.084	9.095	10.11
500	0.632	1.263	1.895	2.526	3.158	3.790	4.421	5.053	5.684	6.316	7.579	8.842	10.11	11.37	12.63

Gals. per Min.	125 feet	150 feet	175 feet	200 feet	250 feet	300 feet	350 feet	400 feet
5	0.158	0.190	0.221	0.253	0.316	0.379	0.442	0.505
10	0.316	0.379	0.442	0.505	0.632	0.758	0.884	1.011
15	0.474	0.568	0.663	0.758	0.947	1.137	1.326	1.516
20	0.632	0.758	0.884	1.011	1.263	1.516	1.768	2.021
25	0.790	0.947	1.105	1.263	1.579	1.895	2.211	2.526
30	0.947	1.137	1.326	1.516	1.895	2.274	2.653	3.032
35	1.105	1.326	1.547	1.768	2.211	2.653	3.095	3.537
40	1.263	1.516	1.768	2.021	2.526	3.032	3.537	4.042
45	1.421	1.705	1.990	2.274	2.842	3.411	3.979	4.548
50	1.579	1.895	2.211	2.526	3.158	3.790	4.421	5.053
60	1.895	2.274	2.653	3.032	3.790	4.548	5.305	6.063
70	2.211	2.653	3.095	3.537	4.421	5.305	6.190	7.074
80	2.526	3.032	3.537	4.042	5.053	6.063	7.074	8.084
90	2.842	3.411	3.979	4.548	5.684	6.821	7.958	9.095
100	3.158	3.790	4.421	5.053	6.316	7.579	8.842	10.11
125	3.948	4.737	5.527	6.316	7.895	9.474	11.05	12.63
150	4.737	5.684	6.632	7.579	9.474	11.37	13.26	15.16
175	5.527	6.632	7.737	8.842	11.05	13.26	15.47	17.68
200	6.316	7.579	8.842	10.11	12.63	15.16	17.68	20.21
250	7.895	9.474	11.05	12.63	15.79	18.95	22.11	25.26
300	9.474	11.37	13.26	15.16	18.95	22.74	26.53	30.32
350	11.05	13.26	15.47	17.68	22.11	26.53	30.95	35.37
400	12.63	15.16	17.68	20.21	25.26	30.32	35.37	40.42
500	15.79	18.95	22.11	25.26	31.58	37.90	44.21	50.53

HORSEPOWER = 33 000 ... ft-lb/min  
 = 550 ... ft-lb/sec  
 = 2544.48 ... Btu/hr  
 = 745.7 ... watts

$(whp) = QH\rho \div 247\ 000 = QP \div 1714$   
 $(bhp) = (whp) \div e_p = QH\rho \div 247\ 000 e_p$   
 $(e_p) = QH\rho \div 247\ 000 (bhp)$


where:  $(whp)$  = water horsepower  
 $H$  = pump head in feet  
 $(bhp)$  = brake horsepower  
 $e_p$  = pump efficiency

Overall efficiency ( $e_o$ ) takes into account all losses in the pump and driver.

$e_o = e_p e_D e_T$   
 where:  $e_D$  = driver efficiency  
 $e_T$  = transmission efficiency

$e_v$  = volumetric efficiency  
 $e_v(\%) = \frac{\text{actual pump displacement } (Q)}{\text{theoretical pump displacement } (Q)} (100)$

Note: For fluids other than water, multiply table values by specific gravity. In pumping liquids with a viscosity considerably higher than that of water, the pump capacity and head are reduced. To calculate the horsepower for such fluids, pipe friction head must be added to the elevation head to obtain the total head; this value is inserted in the first horsepower equation given above.




# TECHNICAL DATA SECTION

## Flow of Water Through Schedule 40 Steel Pipe

Discharge		Pressure Drop per 100 feet and Velocity in Schedule 40 Pipe for Water at 60 F.																	
Gallons per Minute	Cubic Ft. per Second	Velocity		Velocity		Velocity		Velocity		Velocity		Velocity		Velocity		Velocity		Velocity	
		Feet per Second	Lbs. per Sq. In.	Feet per Second	Lbs. per Sq. In.	Feet per Second	Lbs. per Sq. In.	Feet per Second	Lbs. per Sq. In.	Feet per Second	Lbs. per Sq. In.	Feet per Second	Lbs. per Sq. In.	Feet per Second	Lbs. per Sq. In.	Feet per Second	Lbs. per Sq. In.	Feet per Second	Lbs. per Sq. In.
.2	0.000446	1.13	1.86	0.616	0.359	0.504	0.159	0.317	0.061										
.3	0.000668	1.69	4.22	0.924	0.903	0.672	0.345	0.422	0.086										
.4	0.000891	2.26	6.98	1.23	1.61	0.840	0.539	0.528	0.167										
.5	0.001111	2.82	10.5	1.54	2.39	1.01	0.751	0.633	0.240										
.6	0.00134	3.39	14.7	1.85	3.29	1.34	1.25	0.844	0.408										
.8	0.00178	4.52	25.0	2.46	5.44	1.74	1.25	1.06	0.600										
1	0.00223	5.65	37.2	3.08	8.28	2.11	2.10	1.20	0.526										
2	0.00446	11.29	134.4	6.16	30.1	4.22	4.33	2.41	1.09										
3	0.00668			9.25	64.1	5.04	13.9	2.81	1.14										
4	0.00891			12.33	111.2	6.72	23.9	3.01	1.25										
5	0.01114					8.40	36.7	3.17	1.33										
6	0.01337	0.574	0.044			10.08	51.9	3.61	3.84										
8	0.01782	0.765	0.073			13.44	91.1	4.81	6.60										
10	0.02228	0.956	0.108					6.02	9.99										
15	0.03342	1.43	0.224					9.03	21.6										
20	0.04456	1.91	0.375					12.03	37.8										
25	0.05570	2.39	0.561																
30	0.06684	2.87	0.786																
35	0.07798	3.35	1.05																
40	0.08912	3.83	1.35																
45	0.1003	4.30	1.67																
50	0.1114	4.78	2.03																
60	0.1337	5.74	2.87																
70	0.1560	6.70	3.84																
80	0.1782	7.65	4.97																
90	0.2005	8.60	6.20																
100	0.2228	9.56	7.59																
125	0.2785	11.97	11.76																
150	0.3342	14.36	16.70																
175	0.3899	16.75	22.3																
200	0.4456	19.14	28.8																
225	0.5013																		
250	0.557																		
275	0.6127																		
300	0.6684																		
325	0.7241																		
350	0.7798																		
375	0.8355																		
400	0.8912																		
425	0.9469																		
450	1.003																		
475	1.059	1.93	0.054																
500	1.114	2.03	0.059																
550	1.225	2.24	0.071																
600	1.337	2.44	0.083																
650	1.448	2.64	0.097																
700	1.560	2.85	0.112																
750	1.671	3.05	0.127																
800	1.782	3.25	0.143																
850	1.894	3.46	0.160																
900	2.005	3.66	0.179																
950	2.117	3.86	0.198																
1000	2.228	4.07	0.218																
1100	2.451	4.48	0.260																
1200	2.674	4.88	0.306																
1300	2.896	5.29	0.355																
1400	3.119	5.70	0.409																
1500	3.342	6.10	0.466																
1600	3.565	6.51	0.527																
1800	4.010	7.32	0.663																
2000	4.456	8.14	0.808																
2500	5.570	10.17	1.24																
3000	6.684	12.20	1.76																
3500	7.798	14.24	2.38																
4000	8.912	16.27	3.08																
4500	10.03	18.31	3.87																
5000	11.14	20.35	4.71																
6000	13.37	24.41	6.74																
7000	15.60	28.49	9.11																
8000	17.82																		
9000	20.05																		
10000	22.28																		
12000	26.74																		
14000	31.19																		
16000	35.65																		
18000	40.10																		
20000	44.56																		

For pipe lengths other than 100 feet, the pressure drop is proportional to the length. Thus, for 50 feet of pipe, the pressure drop is approximately one-half the value given in the table... for 300 feet, three times the given value, etc. Velocity is a function of the cross sectional flow area; thus, it is constant for a given flow rate and is independent of pipe length.



# TECHNICAL DATA SECTION

## Temperature Conversion Chart

### Instructions For Use:

1. Start in the "Temp" column and find the temperature you wish to convert.
2. If the temperature to be converted is in degrees C, scan to the right column for the degrees F equivalent.
3. If the temperature to be converted is in degrees F, scan to the left column for the degrees C equivalent.

°C	TEMP.	°F	°C	TEMP.	°F	°C	TEMP.	°F
-101	-150	-238	-25	-13	8.6	-3.9	25	77
-95.6	-140	-220	-24.4	-12	10.4	-3.3	26	78.8
-90	-130	-202	-23.9	-11	12.2	-2.8	27	80.6
-84.4	-120	-184	-23.3	-10	14	-2.2	28	82.4
-78.9	-110	-166	-22.8	-9	15.8	-1.7	29	84.2
-73.3	-100	-148	-22.2	-8	17.6	-1.1	30	86
-67.8	-90	-130	-21.7	-7	19.4	-0.6	31	87.8
-62.2	-80	-112	-21.1	-6	21.2	0	32	89.6
-56.7	-70	-94	-20.6	-5	23	0.6	33	91.4
-51.1	-60	-76	-20	-4	24.8	1.1	34	93.2
-45.6	-50	-58	-19.4	-3	26.6	1.7	35	95
-40	-40	-40	-18.9	-2	28.4	2.2	36	96.8
-39.4	-39	-38.2	-18.3	-1	30.2	2.8	37	98.6
-38.9	-38	-36.4	-17.8	0	32	3.3	38	100.4
-38.3	-37	-34.6	-17.2	1	33.8	3.9	39	102.2
-37.8	-36	-32.8	-16.7	2	35.6	4.4	40	104
-37.2	-35	-31	-16.1	3	37.4	5	41	105.8
-36.7	-34	-29.2	-15.6	4	39.2	5.6	42	107.6
-36.1	-33	-27.4	-15	5	41	6.1	43	109.4
-35.6	-32	-25.6	-14.4	6	42.8	6.7	44	111.2
-35	-31	-23.8	-13.9	7	44.6	7.2	45	113
-34.4	-30	-22	-13.3	8	46.4	7.8	46	114.8
-33.9	-29	-20.2	-12.8	9	48.2	8.3	47	116.6
-33.3	-28	-18.4	-12.2	10	50	8.9	48	118.4
-32.8	-27	-16.6	-11.7	11	51.8	9.4	49	120.2
-32.2	-26	-14.8	-11.1	12	53.6	10	50	122
-31.7	-25	-13	-10.6	13	55.4	10.6	51	123.8
-31.1	-24	-11.2	-10	14	57.2	11.1	52	125.6
-30.6	-23	-9.4	-9.4	15	59	11.7	53	127.4
-30	-22	-7.6	-8.9	16	60.8	12.2	54	129.2
-29.4	-21	-5.8	-8.3	17	62.6	12.8	55	131
-28.9	-20	-4	-7.8	18	64.4	13.3	56	132.8
-28.3	-19	-2.2	-7.2	19	66.2	13.9	57	134.6
-27.8	-18	0.4	-6.7	20	68	14.4	58	136.4
-27.2	-17	1.4	-6.1	21	69.8	15	59	138.2
-26.7	-16	3.2	-5.6	22	71.6	15.6	60	140
-26.1	-15	5	-5.0	23	73.4	16.1	61	141.8
-25.6	-14	6.8	-4.4	24	75.2	16.7	62	143.6


### CONVERSION FACTORS

$$^{\circ}\text{C} = (^{\circ}\text{F} - 32) \times 5/9$$

$$^{\circ}\text{F} = (^{\circ}\text{C} \times 9/5) + 32$$

$$0 \text{ Kelvin} = -273.15^{\circ}\text{C}$$

$$0 \text{ Rankine} = -459.69^{\circ}\text{F}$$



**Memorandum**

*SUMNER*  
DATE: 25 April 1988

FROM: Water Treatment Operator Foreman


TO: Leaders and Operators, Bldg. 670

SUBJ: LIME PUMP FLUSHING

1. It appears that some operators are not flushing lime pumps long enough to wash out drain of excess sand and lime. As of this date, when lime pumps are washed out, use water hose and wash excess sand and lime down drain as far as possible.
2. The united cooperation of all personnel will be greatly appreciated.



STANLEY L. MILLER



# Memorandum

5000  
MAIN

**DATE:** 1 March 1988

**FROM:** Water Treatment Plant Operator Foreman


**TO:** Bldg. 20 Operator and Bldg. 670 Leader

**SUBJ:** WATER FLOW AT BLDG. 20

1. The month of February water flows indicated a difference of 8,195,000 gallons. I checked this plant four times during February and I found the raw water reservoir running over three out of the four times. This will no longer be tolerated. Do not exceed 11'8" in the raw water reservoir. If this reservoir is found running over, corrective action will be taken.



STANLEY L. MILLER



# Memorandum

5000  
MAIN

**DATE:** 22 March 1988

**FROM:** Water Treatment Plant Operator Foreman


**TO:** Leaders and Operators of Bldg. 20, 670, and AS-110

**SUBJ:** PH SAMPLING REQUIREMENTS

1. Beginning immediately, the pH analyses will be run on the treated water every two hours. The pH meter will be calibrated one time each day at the beginning of the day shift, with a standard buffer of 4.0, 7.0, and 9.0. However, if pH meter needs calibrating, you may comply with calibration more often. NOTE: Store probe in the pH. 7.0 buffer when not in use - meter on stand by.
2. This increase is to insure a more efficient operation of feeding lime; pH is a good indication of equipment malfunction or poor lime quality.



STANLEY L. MILLER



# Memorandum

5000  
MAIN

DATE: 22 March 1988

FROM: Water Treatment Plant Operator Foreman

TO: Leaders and Operators of Bldg. 20, 670, and AS-110

SUBJ: PH SAMPLING REQUIREMENTS

1. Beginning immediately, the pH analyses will be run on the treated water every two hours. The pH meter will be calibrated one time each day at the beginning of the day shift, with a standard buffer of 4.0, 7.0, and 9.0. However, if pH meter needs calibrating, you may comply with calibration more often. NOTE: Store probe in the pH. 7.0 buffer when not in use - meter on stand by.

2. This increase is to insure a more efficient operation of feeding lime; pH is a good indication of equipment malfunction or poor lime quality.

*Stanley L. Miller*  
STANLEY L. MILLER

NOTE: ① TO ALL LEADERS:  
THIS SAMPLE IS THE TREATED  
SAMPLE THAT COME FROM THE  
BOTTOM OF FILTER

② ALL CALCULATION FOR  
CHEMICAL WILL BE CALCULATED  
ON TREATED FLOW

③ #1 SPERACTOR IS NO LONGER  
BEING CHECKED FOR SAND SIZE,  
ALL SPERACTOR ARE TO BE  
CHANGED EVERY 1500 HR, AS  
BEFORE.


1 -

2-19-88

Mac Foyelle said  
he wanted us to  
adjust the claims  
to 1 PPM here at  
plant, so that  
Paint will have  
a residual of .8

Written By

JOE HARTSOE



# Memorandum

5000  
MAIN

DATE: 1 February 1988

FROM: Water Treatment Plant Operator Foreman

TO: Leaders, Operators of Bldg. 670, 20, AS-110

SUBJ: SAMPLING PROCEDURE - FLUORIDE

1. The State of North Carolina required a fluoride sample be taken from the distribution system of each water plant. The rules governing Public Water Supplies Section: 0606, par. (c) state this. To insure proper sampling procedures, we must increase our sampling of fluoride. The following procedures will be implemented immediately:


a. Bldg. 670 - The operator will pick up samples from TT-38 or Camp Johnson pool daily on his check and bring back to 670 for the fluoride analysis to be run and recorded on log sheet under fluoride sample for distribution system.

b. Bldg. 20 - The well person will pick up sample from Bldg. 540 or 236 daily. Well person will carry sample to Bldg. 20 for operator to run fluoride analysis and record on log sheet under fluoride sample for distribution system.

c. Bldg. AS-110 - The well person will pick up sample from Bldg. TC-501 daily. Well person will carry sample to AS-110 for operator to run fluoride analysis and record on log sheet under fluoride sample for distribution system.

2. Your cooperation will be greatly appreciated in this increase sampling procedure.

  
STANLEY L. MILLER



# Memorandum

DATE: 21 January 1988

FROM: Foreman

TO: Leaders and Operators at 670 & 20


SUBJ: FLOURIDE SAMPLES

The Base Lab is at the present time under staffed. The following procedure will be followed as of this date.

1. Each Plant will run daily Flouride on raw and delivered, and record on log sheet (day shift). You will no longer take samples to Lab each morning.
2. Each Monday you will take samples to Lab as always. This is the only day samples will be taken to Lab. NOTE: This will be the sample taken on Monday morning 12-8 shift.
3. Each shift should run a Flouride and record on log sheet.



STANLEY L. MILLER



670

# Memorandum

5000  
MAIN

DATE: 19 June 1987


FROM: Utilities Systems General Foreman


TO: All Leaders and Foreman, Water and Wastewater

SUBJ: CA-1, SUBMISSION OF

1. Whenever water and wastewater personnel are injured, a Form CA-1, Federal Employees Notice of Traumatic Injury will be filled out by their supervisor. If the employee is sent to Building 15, a CA-1 will be issued to them when they leave. If an employee is injured on the weekends, holidays and after hours, and is sent to the Naval Hospital, a CA-1 will not be provided. The supervisor is responsible for filling out this form upon employee's return to work on the next workday. Leaders should remind their supervisor, upon their return to work, about the injury and leave appropriate data for their supervisor to correctly fill out CA-1.

2. All CA-1's and other pertinent information will be forwarded through me and to Utilities General Foreman, Building 1202.

  
B. M. FRAZELLE, II



# Memorandum

5000  
MAIN

**DATE:** 30 December 1987


**FROM:** Water Treatment Plant Operator Foreman

**TO:** All Leaders and Operators Bldg. 670 Plant

**SUBJ:** CHLORINE CYLINDERS

1. Set scales at 4000 lb. with no cylinder on scales.
2. Place cylinder on scales, subtract tare weight of cylinder. This will give weight of chlorine.
3. Make sure empty cylinder is tagged "empty".
4. Record date full cylinder was placed in service on log sheet and on cylinder.

*Stanley L. Miller*  
STANLEY L. MILLER



CIVILIAN PERSONNEL ADMINISTRATION  
BASE ORDERS

The following is a complete list of Base Orders pertaining to civilian personnel administration. Each department maintains a file of all orders in locations that are accessible to both supervisors and employees upon request.

<u>Number</u>	<u>Subject</u>	<u>Number</u>	<u>Subject</u>
		12540.1A	Merit Pay System (MPS)
		12594.2C	Uniforms and Handtools; regulations concerning
		12610.1G ch1	Hours of Work
		12630.1G ch1	Absence and Leave for Civil Service Employees
12000.1R	Position Maint. Review	12711.1A	Official Time for Representational Functions
12000.2C	Civilian Personnel Mgmt. Program	12713.4B	Upward Mobility for Civil Service Employees
12270.1A ch1	Travel Orders for Civil Service Personnel	12713.5F	MCB Update of Affirmative Action Program Plan Goals for FY 83-87
12275.1A	Self-Eval. of Civilian Personnel Mgmt.	12713.6B	EEO Program
12293.1A	Maint., Use, and Disposition of Civil Service Personnel Records and Files	12713.7	Sexual Harassment
12300.4C	DOD Program for Stability of Civilian Employment	12715.1	Clearance Requirements of Civil Service Employees Preliminary to Separation for any Reason
12306.1	Handicapped and Disabled Veterans Program	12750.1H	Discipline, Conduct, and Adverse Actions
12315.1	Probationary Period for Managers and Supervisors	12771.1	Department of the Navy Grievance Procedure
12335.1C	Merit Staffing Program	12790.1E	Service to Employees (General)
12335.2B	Use of Details and Temporary Promotions of 120 Calendar Days or Less	12790.2E	MCB Camp Lejeune Employees' Recreation and Welfare Association
12351.1D	Reduction-in-Force (RIF)	12790.4D	Dependents' Aid Association
12410.3G	Civilian Employee Training and Development Program	12792.1C	Medical Examinations and Services for Civil Service Employees
12430.1L	Performance Appraisals and Ratings of Civil Service Employees	12792.2B	Civilian Employee Assistance Program (CEAP)
12432.1	Reduction in Grade and Removal Based on Unacceptable Performance	12810.1	Federal Employees' Compensation Program
12451.1G ch1,2	Incentive Awards Program/Military Cash Awards Program		*****
12511.1B	Position Classification		
12531.7C	Salary Increases for Civil Service Employees		
12531.8B	Selection of Salary and Wage Step Rates for Civil Service Employees		There's always room for improvement; it's the biggest room in the house.
12532.1N	Wage Schedules for Trades and Labor Employees		*****
12532.2A ch 1	Grading of Trades and Labor Positions under the Federal Wage System		Call 451-3928 - The CLNC HOTLINE to report incidents of WASTE, FRAUD, ABUSE, CORRUPTION

# WHAT EVERY WOMAN SHOULD KNOW



**F**or years we've known how harmful cigarette smoking is to men. Now we're finding out how harmful it is to women. Since women haven't smoked as long or as heavily as men, the damage has become apparent more slowly. Until recently, we could cling to the illusion that women had a built-in protection from the consequences of cigarette smoking.

Unhappily, it was just an illusion. Now the evidence is in. So grave and so far-reaching are the findings that they warrant thoughtful consideration by women of all ages who smoke, or are tempted to—women who care about their own bodies and are concerned about the effect their actions may have on others.

Heart disease, stroke, emphysema, cancers of the mouth and larynx. These are just a few of the other serious diseases women smokers are prey to. Women who smoke also spend 15% more days sick in bed each year with less serious ailments, and lose nearly three

times as many work days as women who don't smoke.

For a pregnant woman, the harmful effects of smoking also extend to her unborn child. Nicotine and carbon monoxide from cigarettes can retard the fetus' growth so that the infant is born

below normal weight. Small babies frequently have difficulty getting a good start in life, and their physical and emotional development during childhood may be affected.

In addition, women who smoke during pregnancy are more likely to have a stillborn infant, or a baby who dies soon after birth.

Teen-age girls, too, seem to be caught in the smoking spiral. Smoking in this group is rising sharply. Originally an activity which appealed primarily to boys, smoking has now become a habit for more than 15 percent of girls between 12 and 18—just a fraction under the number of boys the same age who smoke. Those who start young tend to smoke heavily, and it is heavy smokers who run the greatest risk. Studies show that children are more likely to smoke if their parents or older sisters and brothers smoke.

Now that the damaging facts are in, those of you who smoke may want to rethink your feelings about smoking—your reasons for starting in the first place, why you still do it, whether you even enjoy it. Ask yourself a hard question: is your cigarette habit really worth the consequences—and harder still, shouldn't you try to quit?

Can you quit?

Many people don't find the actual quitting very difficult, once they have made up their minds. Thirty million women and men have been able to do it.

The decision is yours now.

If you decide to quit, here are a few suggestions that might make it easier:

1. List the reasons for and against smoking.
2. Change to a low tar, low nicotine brand.
3. Select a day to quit.
4. Chart your smoking habits for two weeks: how many cigarettes, when, which is the most and least important.
5. Each night, repeat at least ten times one of your reasons for not smoking.
6. Eliminate one cigarette from your routine: the most or least desired.
7. Quit on the day you selected. Keep busy: go to the movies, exercise, take long walks. Use substitutes, sip water, chew gum, eat raisins or carrots, chew a clove.

Don't be discouraged if you don't make it the first time. Try again. Some ex-smokers say they tried and failed many times before succeeding. The important thing is they did try, and they did finally succeed.

You can, too.

\*\*\*\*\*

## 'LOOK-ALIKE' DRUG ABUSE SPREADING

The use of counterfeit or "look-alike" drugs is a peculiar form of drug abuse which is sweeping the country, according to the U. S. Department of Justice's Drug Enforcement Administration.

Look-alikes are carefully designed to resemble prescription drugs, such as amphetamines, barbituates, tranquilizers and narcotic pain killers which are sold, in many cases, illegally on the street. They are known by the same names as their dangerous counterparts: Black Beauties, Dexies, Yellows, Christmas Trees and Rainbows. But look-alikes contain only substances such as caffeine, ephedrine, phenylpropanolamine, acetaminophen and other over-the-counter non-prescription drugs.

The public health dangers of look-alikes have become apparent. The user who thinks he has been purchasing "speed" (an amphetamine, such as dexedrine) or "ludes" (methaqualone) and has become used to taking several look-alike capsules or tablets at a time in order to "get the full effect" runs the risk of serious overdose or death if one day he ingests the same number of the "real thing."

Also the look-alikes, themselves, can have serious effects. The number of emergency room incidents attributable to these drugs has risen dramatically in the past year and more than a dozen deaths caused by look-alikes have been reported.

These drugs not only cause problems for those who take

them, they are causing serious problems for state and federal officials and medical personnel. Since the pushers are not selling a controlled substance, legal authorities are almost powerless. Also, overdose of look-alikes are difficult to treat since the actual substance ingested may not be known.

If it is suspected that such a substance (look-alike or other unknown drug) has been taken, contact a physician immediately and try to obtain a capsule (or tablet) of the drug so that it can be identified.

\*\*\*\*\*

## THE CIVILIAN EMPLOYEE ASSISTANCE PROGRAM

The Civilian Employee Assistance Program was established to provide assistance to those employees with alcohol or other drug dependence, or personal problems which are adversely affecting their job performance. If you have such a problem, Dottie Pullicino is available to discuss it with you and to offer assistance. Her office is in Building 33, Civilian Personnel Division; telephone extensions, 1458/1579.

\*\*\*\*\*

When you put part of your savings into U. S. Savings Bonds you're helping to build a brighter future for your country and for yourself.

# Civilian Guidepost

Compiled and Edited by

CIVILIAN PERSONNEL DIVISION, MARINE CORPS BASE, CAMP LEJEUNE, NORTH CAROLINA

Issuance of this periodical approved in accordance with Department of the Navy Publications and Printing Regulations

VOLUME 29 NO. 3

11 FEBRUARY 1983



COMMANDING GENERAL  
Marine Corps Base  
Camp Lejeune, North Carolina 28542

19 January 1983

TO ALL PERSONNEL:

I have received numerous reports of assistance provided to needy families by our military and civilian personnel through their work organizations during the Christmas season.

During these times when many of our citizens in the surrounding communities are suffering economic hardship, such actions exemplify the true spirit of Christmas.

To all of you who so generously participated to bring a measure of hope and cheer to these needy families, I commend you for a job well done.

D. J. FULHAM  
Brigadier General, U. S. Marine Corps

\*\*\*\*\*

## CHANGE IN DISCONTINUED SERVICE RETIREMENT ELIGIBILITY

A recently enacted Public Law has amended the retirement law to restrict eligibility for discontinued service retirement. Prior to 1 October 1982, employees who were involuntarily separated from the service other than for misconduct or delinquency were eligible for discontinued service retirement if they were at least 50 years old with 20 years service, or any age with 25 years service, even if they declined offers of positions at the same grade and pay. Under the new law, an employee who is involuntarily separated from the service on and after 1 October 1982, will not be eligible for discontinued service retirement if the employee has declined a reasonable offer of another position in the employee's agency for which qualified, which is not lower than two grades or pay levels below the person's current position, which is in the employee's same commuting area.

\*\*\*\*\*

St. Valentine's Day - 14 February 1983

## WITHHOLDING WITHIN-GRADE INCREASES LINKED TO BASIC PERFORMANCE APPRAISAL PROGRAM

The Department of the Navy (DON) has issued Civilian Personnel Instruction (CPI) 431 which links the withholding of within-grade increases to DON's Basic Performance Appraisal Program. Base Order 12531.1C, recently issued, incorporates the essential requirements of that CPI.

The same performance standards established under the Performance Appraisal Program are the standards which must be considered in deciding to withhold or grant a within-grade increase. The requirement under the previous order for advance written notice of deficiencies in performance has been eliminated. Instead, the performance appraisal process, particularly the most recent appraisal, will be the mechanism for warning an employee that his or her performance is not satisfactory. A rating of less than satisfactory in one or more critical elements requires the withholding of a within-grade increase unless justified in writing.

The new procedure for the withholding of within-grade increases should make it easier to identify and correct employees with performance-related problems.

Both General Schedule and Federal Wage System employees may have within-grade increases withheld; however, the procedures to follow differ in several respects for each group. Specifics are detailed in the new Base Order. Questions concerning the order may be directed to the Classification Branch, extension 1532.

\*\*\*\*\*

## DEVELOPING YOUR BENEFICIAL SUGGESTION

Develop your suggestion! To ensure the best possible chance of your idea winning approval (and dollar awards) nail it down with all the necessary details.

Civilian Courier

\*\*\*\*\*

## DID YOU KNOW

A gasoline container with only a small amount of gas in it creates a gas-air mixture much more explosive than a container three-quarters full. Think Safety!

STAFFING ANNOUNCEMENTS

Open Continuously

Practical Nurse, GS-3 TARGET GS-4, Ann. No. 63-81
Clerk, GS-2 and GS-3, Ann. No. 162-81
Laundry Worker, WG-2, and Presser, WG-2, Ann. No. 165-81
Clerk-Stenographer, GS-3, and Clerk-Typist, GS-3, Ann. No. 168-81
Laborer, WG-2 and WG-3, Ann. No. 176-81
Food Service Worker, WG-2, Ann. No. 188-81
Clerk-Stenographer, GS-4, Ann. No. 78-82

Open for Specified Period

Boiler Plant Operator General Foreman, WS-13, Ann. No. 14-83, closes 15 February 1983
Electrician General Foreman, WS-12, Ann. No. 15-83, closes 15 February 1983

UPCOMING ANNOUNCEMENTS

WATCH YOUR OFFICIAL BULLETIN BOARDS

Supply Clerk, GS-5 TARGET Supply Technician, GS-6
Accounting Technician, GS-4
Accounting Technician, GS-5
Purchasing Agent, GS-4 TARGET GS-5
Purchasing Agent, GS-5

\*\*\*\*\*

HEALTH BENEFITS COVERAGE FOR THE DISABLED CHILD

The law provides that an employee's self and family enrollment includes unmarried children over age 22 who are incapable of self-support because of physical or mental incapacity which existed before they reach age 22. Financial dependency is not a factor--a determination of incapacity for self-support is based entirely on medical considerations.

Medical certification and a request for coverage may be submitted to the Civilian Personnel Division at the time of initial enrollment or at any later time; however, for a child who has been covered in a self and family enrollment, certification should be submitted at least 30 days before the child attains age 22. Depending on the nature of the handicap, coverage may be extended for a limited time or permanently. If the extension is for a limited period, and incapacity continues beyond that period, further extension of coverage may be approved upon presentation of medical certification.

If you have self and family coverage and have a child whom you believe falls in this category, you should contact the Employee Relations Branch, extension 1579, for further information.

\*\*\*\*\*

IT'S A FACT

Most automobiles get about 20 percent more miles per gallon on the highway at 55 mph than they do at 70 mph.

KEROSENE HEATERS: USE WITH CAUTION

If you are thinking of getting a kerosene heater, the National Safety Council offers the following advice:

First, check to see if kerosene heaters are allowed where you live. Their use is prohibited on military bases and in military housing and government buildings. Some states and counties restrict or limit their use.

If the sale and use is not prohibited in your area, look for the newer models with built-in safety features. Features to look for are: safety shut-off devices, guard rails, low center of gravity (to reduce tipping and spilling), double walls and push-button "on" switch so you don't have to use matches.

Burn only kerosene. Never use gasoline, white gas, camp-stove fuel or other fuels. They are extremely hazardous if used in kerosene heaters.

The kerosene should be Grade #1 (it looks clear, like water). Yellow or colored kerosene will smoke, smell and mess up your wick.

Keep your kerosene in an approved container, clearly marked KEROSENE, away from living quarters.

Refill the heater away from living quarters when the heater is cool. Use a siphon pump to keep from spilling fuel.

Place the heater away from curtains, furniture, papers, clothes or other things that will burn.

Some heater surfaces will get hot. Keep children away and instruct them to not touch the controls. Consider putting up a barrier to prevent them from contacting the heater.

Make sure enough air is circulating through the room. Open the door to an adjacent room. Open a window slightly in totally closed rooms.

Because the heaters have an open flame, don't use flammables like aerosol sprays, lacquers or gasoline in the same room.

When you turn the heater off, be sure the flame is all the way out.

Read and follow the manufacturer's instructions for using and maintaining the heater.

\*\*\*\*\*

MEETINGS

AFGE MEETING: 7:30 p.m., 17 February 1983, AFGE Office Building, Gum Branch Road.

FMA MEETING: 4:30 p.m., 24 February 1983, NCO Club, Bldg. 425. All supervisors are invited to attend.



UNITED STATES MARINE CORPS

Base Maintenance Division  
Marine Corps Base  
Camp Lejeune, North Carolina 28542

IN REPLY REFER TO  
11380  
MAIN  
29 Jul 85

From: Director, Utilities Branch  
To: Air Conditioning Equipment Mechanic Foreman

Subj: CHECK IN PROCEDURES

1. To promote plant and personnel safety within the Cold Storage Plant, the following check in procedures will be implemented upon receipt of this letter:

a. The Water Treatment Plant, phone number: 5988 will be called at 1600, 1800, 2000, 2200, 2400, 0200, 0400, and 0600 daily on weekdays. Telephone calls will also be made every two hours throughout the 24-hour period on Saturdays, Sundays, and holidays. During the months that don't require a 12/8 operator, the 4/12 shift operator will also call between the time frame of 2330-2400.


b. Anytime telephone calls are not received on schedule, the Water Treatment Plant Operator will call the Cold Storage Plant, phone 3567, to insure that no accident has occurred. If the operator cannot be reached, the Water Treatment Plant Operator will initiate action by sending the Helper on duty to the Cold Storage Plant to investigate the problem and report same to the Water Treatment Plant Operator. Anytime that no one is available at the water plant, the operator will call and report the problem to Mr. Chesley Thigpen, phone: 324-4319 (Richlands), or Mr. Arthur Becker, phone: 347-5287 (Jacksonville), or Mr. D. L. Southerland, phone: 298-3654 (Beulaville).

c. After checking the Cold Storage Plant, if an accident or any other difficulty exist, the operator will get medical aid and call Mr. Chesley Thigpen or Mr. Arthur Becker at the above mentioned telephone numbers.

d. Cold Storage Plant Operator will note on log sheet time call was placed to the Water Treatment Plant Operator. Water Plant Operator will note on log sheet time call was received from Cold Storage Plant.

*G. S. Johnson, Jr.*  
G. S. JOHNSON, JR.

Copy to:  
WaterTreatSec



UTILITIES BRANCH  
EMERGENCY CALLBACK LIST

DIRECTOR

JOHNSON, GOLD S. JR.

SWANSBORO

393-8417

ASSISTANT DIRECTOR

SOUTHERLAND, DAVID L.

CHINQUAPIN

298-3654

-----  
STEAM GENERATION SECTION

SHEPARD, KENNETH R.  
Boiler Plant Operator General Foreman

RICHLANDS

285-4225

MEADOWS, BOBBY E.  
Boiler Plant Operator Foreman

MAYSVILLE

743-7971

JONES, JAMES V.  
Boiler Plant Equipment Mechanic Foreman

CHINQUAPIN

324-2211

HUMPHREY, MORRIS  
Pipefitter Foreman

RICHLANDS

324-5718

-----  
WATER & WASTEWATER TREATMENT SECTION

PRICE, WILLARD R.  
Utility Systems General Foreman

PINK HILL

298-3629

FRAZELLE, Byron M.  
Water Treatment Plant Operator Foreman

JACKSONVILLE

353-7595

DAVIS, MACK D. ✓  
Sewage Disposal Plant Operator Foreman

SNEADS FERRY

327-3757

LISIEWSKI, JOE S.  
Plumbing Foreman

JACKSONVILLE

(353-9576)

-----  
UMACS SECTION

ENGLE, PAT  
General Engineer

HUBERT


326-1658

-----  
COLD STORAGE SECTION

BECKER, ARTHUR F.  
Air Conditioning Equipment Mechanic  
Foreman

Jacksonville

347-5287




ELECTRICAL DISTRIBUTION SECTION

MACMILLAN, L. T.  
Electrician Foreman

WALLACE

285-7281





The gasoline day tank is located under the base of the generator. The float reset button is located front right. This button will allow you to also feed fuel manually from the main tank.

When starting engine, if you receive a overcrank alarm, try to start generator again, the engine may be cold or out of fuel.

The alarm in red will shut down the engine. You must reset each fail before the engine will start. The reset is the red lite, the alarm disconnect only silences the horn.

Starter overspeed is set at 600 RPM and then it will pull out and give an alarm.

If the engine shuts down for any reason it will not start until 70 seconds has elapsed.

The engine should be warm to touch at all times, this means heater jacket is working.

The oil stick is on left and should be checked each start up.

To start generator in manual turn start/stop switch to manual. To stop generator turn start/stop switch to auto and leave in auto position.

The hertz should read 60. If readjustment is required, call leader on duty.

The red button on the left behind the panel shuts off generator (emergency shut down). It must be reset inside box, top middle reset. Turn start, stop, reset, switch to reset then back to auto. To check system if commercial power is on, place test switch to test, generator will start, power will go off for 3 seconds, switch will transfer, pumps will go off for 50 seconds. The pumps that were in auto will come back on and run for 5 minutes. Pumps will go off for 50 seconds, switch will transfer back to commercial power. Generator will run for 5 more minutes.


Make sure that leader is called before test.



11

When commercial power goes off generator will start and system should transfer. Operator will place pump needed in hand and press start button. Cut pumps not required to off position until commercial power is restored at which time system will transfer back to commercial power. Generator will run for 5 minutes and shut down. Place all pumps back to auto.

If this system fails to transfer automatically, follow instructions on transfer panel for manual transfer.




PUMPING RATES + SCREEN LEVELS  
New Wells.

John Miller

WELL #	DOWN TO:	UPPER SCREEN	PUMP RATE
1	68'0"	78'0"	250
2	62'0"	72'0"	200
3	<del>50'0"</del> 90'0"	100'0"	250
4	50'	60'	250
5	75'	85	300
6	74'	84'	200
7	60'	70'	250
8	120'	130'	250
9	80'	90'	300
10	116'	126'	300
11	65'	75'	200
12	60'	70'	200
13	50'	60'	200
14	120'	130'	350'

John Miller 1-638-3476




NOTICE

The following personnel will check the fire extinguishers for proper pressure, seal on pin, and initial card monthly. Check weekly inspection sheet when completed.

Hadnot Point  
TT and Camp Johnson  
MCAS, MOQ and CG  
Holcomb Boulevard  
OB, CHB, RR  
Shop (at Bldg. 762)

Pehowic  
Hartsoe  
Ellis  
Holland  
Sumner  
Rich

Stanley L. Miller



*Utilities*



UNITED STATES MARINE CORPS  
BASE MAINTENANCE DIVISION  
MARINE CORPS BASE  
CAMP LEJEUNE, NORTH CAROLINA 28542-5000


IN REPLY REFER TO  
12451  
MAIN  
05 OCT 1987

From: Base Maintenance Officer


Subj: EMERGENCY PROCESS CODE

1. Effective immediately the emergency access code "Red" will be utilized by maintenance personnel to gain access to the Base Maintenance radio frequency network in case of an emergency. Upon hearing this code, all personnel are to vacate the network to permit the individual to seek assistance.

2. Your cooperation and assistance is appreciated in this matter.

  
M. G. LILLEY


DISTRIBUTION: C




**DATE:** 30 September 1987  
**FROM:** Water Treatment Plant Foreman  
**TO:** All Water Treatment Plant Personnel  
**SUBJ:** PLANT INSPECTIONS

1. I would like to express my appreciation for a job well done. Over the past few months, there has been some changes in operation and inspection of plants by leaders. Most everyone has cooperated to the fullest in maintaining the plant appearance and quality of water required.

2. I like to think of the Water Treatment personnel as a football team. Each player has an assignment when they go out on the field. When the assignment is done properly by each player, the team wins. From my standpoint at the present time, you are a winning team.

  
STANLEY L. MILLER




**DATE:** 30 September 1987  
**FROM:** Utilities Systems General Foreman  
**TO:** Water Treatment Plant Operator Foreman  
Wastewater Treatment Plant Operator Foreman

**SUBJ:** PLANT INSPECTIONS

1. A review of utility plants, plant inspections and chemical and bacterial analysis reveals that plant operations and appearance are exceptional. Please convey to all personnel my sincere appreciation and a job well done.
2. The past year has brought many changes in personnel and operating procedures. Only through each employees' initiative, cooperation and assistance can we continue to meet the mission of the Water and Wastewater Treatment Section. Please solicit each employee for new ideas, improved operations and their continued support.
3. Let's continue to keep up the good work.

  
B. M. FRAZELLE, TI



WE LEADER'S


CAN FILL OUT

DISPENSARY

PERMIT FOR

HEARING TEST

m  
7



3. COPIES

OCCUPATIONAL HEALTH PERMIT  
MCBCL 5100/3

- INSTRUCTIONS:
1. Complete in Triplicate.
  2. Return Original to Supervisor; 1 Copy to Civilian Personnel; 1 Copy to Base Safety Manager.
  3. If an Occupational Injury, Form CA-17 with Part A Completed MUST Also be Submitted.

THIS SECTION TO BE COMPLETED BY SUPERVISOR

TO: OCCUPATIONAL HEALTH NURSE, BUILDING 15, CAMP LEJEUNE, N.C. 28542

FROM: (Title of Supervisor, Shop or Office, and Location)

NAME OF EMPLOYEE (First, Middle, Last) *YOU*  
*Leon S. Parker*

PAYROLL NO. *2383-14908* SOCIAL SEC. NO. *246-40-0308*

JOB TITLE *Water Plant Operator*

TIME LEFT JOB TIME RETURNED

REASON FOR REFERRAL

- INJURY  ILLNESS  EMPLOYEE'S REQUEST  OTHER (Specify) *your choice*

DATE AND TIME OF INJURY DATE REFERRED TO CLINIC OCCUPATIONAL

YES  NO  QUESTIONABLE

REMARKS

NAME OF SUPERVISOR (Print) *D. E. Hill* SIGNATURE \_\_\_\_\_ PHONE *5988* DATE *11-12-86*

THIS SECTION TO BE COMPLETED BY MEDICAL OFFICER

TIME REPORTED TIME RELEASED OCCUPATIONAL

YES  NO  QUESTIONABLE

DEGREE OF INJURY

- FIRST AID  DISPENSARY  HOSPITAL  PERSONAL PHYSICIAN  SENT HOME  OTHER (Explain in Remarks)

DISPOSITION OF EMPLOYEE

RETURN FOR FURTHER TREATMENT	TIME	DATE
RETURN TO WORK		
DISCHARGED. TREATMENT COMPLETED		
RETURN TO LIMITED DUTY AS INDICATED BELOW		
NO LIFTING, PULLING OR CARRYING IN EXCESS OF _____ LBS.		DESK JOB ONLY
NO EXCESSIVE WALKING, STANDING OR BENDING		NO DRIVING GOVERNMENT VEHICLE
NO EXPOSURE TO SOLVENTS, GREASES, OILS, DETERGENTS, ETC.		NO WORKING AROUND MOVING MACHINERY
NO WALKING ON UNEVEN OR SLIPPERY SURFACES		NO WORKING ON LADDERS, SCAFFOLDING, ETC.
NO EXPOSURE TO EXTREME TEMPERATURE OR HUMIDITY		ONE HAND JOB ONLY
OTHER (Explain)		


REMARKS

NAME OF MEDICAL OFFICER (Print or Type) SIGNATURE OF MEDICAL OFFICER DATE

PRIVACY ACT STATEMENT

Authority: SECNAVINST 5100.10B and OPNAVINST 5100.14  
 Principal Purpose: To control and monitor treatment and disposition of civilians of Naval Dispensaries in cases of occupational injury or illness.  
 Routine Use: To ensure prompt investigation of occupational injuries, and to initiate any necessary immediate corrective action.  
 Disclosure: Voluntary. Treatment will be provided without regard to employee's willingness to divulge all or part of the requested information.

Faint, illegible text is visible in the background, possibly bleed-through from the reverse side of the page.



TO LEADERS AND OPERATORS AT 670:

When recording flow used, the raw water meter on the computer for raw water flow reading. This is a total reading for the day.

When recording delivered water add HBFLW and TRMFLW together for the delivered water reading. This will be a total daily flow.


Record old meter reading on back of Log Sheet for information only.

A handwritten signature in cursive script, appearing to read 'S. J. ...', is located in the lower right quadrant of the page.



# BOOSTER PUMP ON H.B.

Door  
3'-0" x 6'-6" x 1 $\frac{3}{4}$ "




The contractor shall provide and install a horizontal split case centrifugal pump complete & ready to operate. Pump shall have characteristics as follows when the suction head is 46 psi ga. (106')

GPM	Head feet	Total head in system	BHP	EFF
600	68'	174'	12.6	80%
650	64'	170'	12.8	81%
700	60'	166'	12.9	82%
750	55'	161'	12.8	82%
800	48'	154'	12.5	80%

Pump shall be direct connected, electric motor driven, 208 V. 60 cy. 3 $\phi$ , with a 15 HP motor.

## PLAN

Scale 1/4" = 1'0"



TARAWA TERRACE PUMP SEQUENCE

4-6-87

Step #1 - Pump 3 - All others off

Step #2 - Pump #1 or #2 on (Alternate) - Pump #3 & #4 off.


Step #3 - Pump #1 and #2 on - Pump #3 & #4 off.

Step #4 - Pump #4 on - All others off

#4 Pump in Auto 6/26/87

Note: ~~\*This pump in OFF position - waiting parts for repair.~~

DATA BASE - DISCRETE.  
BOP 153 - GENERATOR FOR 670  
IN R.W. PUMP HOUSE.



Thursday July 23, 1987

- 1) Point Id : MPC
  - 2) Description : WELL PUMP CONTROL
  - 3) Mult. Step Control : Enable
  - 4) Control Direction : Falling
  - 5) Num Control Levels : 1 (0 Disables Control)
- |  |               |            |               |
|--|---------------|------------|---------------|
|  | Control Level | Point Id   | Current Value |
|  | 1             | 6) RWTRESV | 7) 17.0       |
|  | 2             | 8)         | 9) 0          |
|  | 3             | 10)        | 11) 0         |

12) Number Of Steps :	2					
	Step	ON Setpoint	OFF Setpoint	Time Delay	Timer	Step Status
	1	13) 15.9	14) 16.9	15) 20	16)	17) Off
	2	18) 15.9	19) 16.9	20) 20	21)	22) Off
	3	23) 15.9	24) 16.9	25) 20	26)	27) Off
	4	28) 0.0	29) 0.0	30) 20	31)	32) Off
	5	31) 0.0	34) 0.0	35) 0	36)	37) Off
	6	38) 0.0	39) 0.0	40) 0	41)	42) Off

Step	Pump Control Assignments									
1	43) WP1	44) WP2	45) WP3	46) WP4	47) WP5					
	48) WP6	49) CBP1	50) WP8	51) WP9	52) WP10					
2	53) WP7	54) WP647	55) WP648	56) WP649	57) WP650					
	58) WP646	59) WP644	60) WP643	61)	62)					
3	63)	64)	65)	66)	67)					
	68)	69)	70)	71)	72)					
4	73)	74)	75)	76)	77)					
	78)	79)	80)	81)	82)					
5	83)	84)	85)	86)	87)					
	88)	89)	90)	91)	92)					
6	93)	94)	95)	96)	97)					
	98)	99)	100)	101)	102)					

103) Alternate Option : No

	Pump Id	alternate with	Pump Id
	104)	105)	
	106)	107)	

Volume 13: 1987

Point ID :  
 Description :  
 Full Stop Control :  
 Control Direction :  
 Run Control Levels :  
 Control Level :  
 1  
 2  
 3

Step	Number Of Steps	Setpoint	Setpoint	Time Delay	Time	Step Status
1	1	10.0	10.0	30	10	100
2	2	10.0	10.0	30	10	100
3	3	10.0	10.0	30	10	100
4	4	10.0	10.0	30	10	100
5	5	10.0	10.0	30	10	100
6	6	10.0	10.0	30	10	100

Step	Point ID	Time Delay	Time	Step Status
1	100	30	10	100
2	100	30	10	100
3	100	30	10	100
4	100	30	10	100
5	100	30	10	100
6	100	30	10	100

Point ID :  
 Alternate with :  
 100  
 100

07/23/87 16:00:43

Base Level Control Point

Thursday July 23, 1987

- 1) Point Id : RWPC
  - 2) Description : RAW WATER PUMP CONTROL
  - 3) Mult. Step Control : Disable
  - 4) Control Direction : Falling
  - 5) Num Control Levels : 1 (0 Disables Control)
- |               |           |               |
|---------------|-----------|---------------|
| Control Level | Point Id  | Current Value |
| 1             | 6) HBFMRL | 7) 8.1        |
| 2             | 8) TRMRSV | 9) 9.9        |
| 3             | 10)       | 11) 0         |

12) Number Of Steps	Step	ON Setpoint	OFF Setpoint	Time Delay	Timer	Step Status
1	13)	8.7	14) 9.2	15) 20	16)	0 17) On
2	18)	7.9	19) 8.3	20) 20	21)	0 22) Off
3	23)	7.5	24) 7.9	25) 20	26)	0 27) Off
4	28)	7.0	29) 7.5	30) 20	31)	0 32) Off
5	31)	0.0	34) 0.0	35) 0	36)	0 37) Off
6	38)	0.0	39) 0.0	40) 0	41)	0 42) Off

Step	Pump Control Assignments			
1	43) RWP1	44) RWP2	45) RWP3	46) RWP4
2	48) RWP1	49) RWP2	50) RWP3	51) RWP4
3	53) RWP1	54) RWP2	55) RWP3	56) RWP4
4	58) RWP1	59) RWP2	60) RWP3	61) RWP4
5	63) RWP1	64) RWP2	65) RWP3	66) RWP4
6	68) RWP1	69) RWP2	70) RWP3	71) RWP4
	73) RWP1	74) RWP2	75) RWP3	76) RWP4
	78) RWP1	79) RWP2	80) RWP3	81) RWP4
	83) RWP1	84) RWP2	85) RWP3	86) RWP4
	88) RWP1	89) RWP2	90) RWP3	91) RWP4
	93) RWP1	94) RWP2	95) RWP3	96) RWP4
	98) RWP1	99) RWP2	100) RWP3	101) RWP4

103) Alternate Option : No

Pump Id	alternate with	Pump Id
104) RWP1	105) RWP2	
106)	107)	

Print Cnst Print Sort Rep Const Select Test < ESC > =====>

07:52:07 16:00:43

Unit 100

1) Point 14 : RUPC  
 2) Description : RUPC WATER PUMP CONTROL  
 3) Full Stop Control : Disable  
 4) Control Direction : Follow  
 5) Run Control Level : 1 (B Disables Control)  
 Control Level : 1  
 Point 14 : Current Value : 1  
 07:52:07 : 1  
 07:52:07 : 1  
 07:52:07 : 1

Station	Time	Time Delay	Off Setpoint	On Setpoint	Number Of Steps
100	07:52:07	0	0.0	0.0	6
100	07:52:07	0	0.0	0.0	5
100	07:52:07	0	0.0	0.0	4
100	07:52:07	0	0.0	0.0	3
100	07:52:07	0	0.0	0.0	2
100	07:52:07	0	0.0	0.0	1

Step	RWP1	RWP2	Time	Time Delay	Off Setpoint	On Setpoint
1	000	000	07:52:07	0	0.0	0.0
2	000	000	07:52:07	0	0.0	0.0
3	000	000	07:52:07	0	0.0	0.0
4	000	000	07:52:07	0	0.0	0.0
5	000	000	07:52:07	0	0.0	0.0
6	000	000	07:52:07	0	0.0	0.0

100) Alternate Station : No  
 100) RWP1 : 100  
 100) RWP2 : 100  
 Alternate with : 100  
 Pumps : 100

Print Out: [unclear] Rep Const Report

Thursday July 23, 1987

- 1) Point Id : CFC
- 2) Description : CHEMICAL FEED CONTROL
- 3) Mult. Step Control : Enable
- 4) Control Direction : Rising
- 5) Num Control Levels : 1 (0 Disables Control)

Control Level	Point Id	Current Value
1	6) PINFLW	7) 0.00
2	8)	9) 0
3	10)	11) 0

Step	Number Of Steps	ON Setpoint	OFF Setpoint	Time Delay	Timer	Step Status
1	13)	0.50	14) 0.35	15) 10	16)	0 17) Off
2	18)	0.50	19) 0.35	20)	21)	0 22) Off
3	23)	3.10	24) 2.50	25)	26)	0 27) Off
4	28)	4.10	29) 3.50	30)	31)	0 32) Off
5	31)	0.00	34) 0.00	35)	36)	0 37) Off
6	38)	0.00	39) 0.00	40)	41)	0 42) Off

Step	Pump Control Assignments					
1	43) LF2	44) LP2	45) LP3	46) FLF1	47) FLP1	
	48) LSU3	49) LSU2	50) LSU1	51) LP1	52) LP6	
2	53) LSU4	54) AFP1	55) AFP2	56) LP4	57) LSU5	
	58)	59)	60)	61)	62)	
3	63)	64)	65)	66)	67)	
	68)	69)	70)	71)	72)	
4	73)	74)	75)	76)	77)	
	78)	79)	80)	81)	82)	
5	83)	84)	85)	86)	87)	
	88)	89)	90)	91)	92)	
6	93)	94)	95)	96)	97)	
	98)	99)	100)	101)	102)	

103) Alternate Option : No Pump Id alternate with Pump Id  
 104) 105)  
 106) 107)

Control Level  
 2) Run Control Levels  
 3) Control Direction  
 4) Halt Step Control  
 5) Description  
 6) Point ID

Step	Step Number	Step	Step Number	Step	Step Number
1	100	1	100	1	100
2	101	2	101	2	101
3	102	3	102	3	102
4	103	4	103	4	103
5	104	5	104	5	104
6	105	6	105	6	105

Step	Step	Step	Step	Step	Step
1	100	1	100	1	100
2	101	2	101	2	101
3	102	3	102	3	102
4	103	4	103	4	103
5	104	5	104	5	104
6	105	6	105	6	105

1997 Alternate Option : No  
 Pump ID : 100  
 Alternate with : 100

Thursday July 23, 1987

- 1) Point Id : HGPC
  - 2) Description : HGLCMB BLVD PUMP CONTROL
  - 3) Mult. Step Control : Disable
  - 4) Control Direction : Falling
  - 5) Num Control Levels : 1 (0 Disables Control)
- |  |               |             |               |
|--|---------------|-------------|---------------|
|  | Control Level | Point Id    | Current Value |
|  | 1             | 6) PPETLVL  | 7) 25.7       |
|  | 2             | 8) PPETLVL  | 9) 25.7       |
|  | 3             | 10) PPETLVL | 11) 25.7      |

12) Number Of Steps	: 3							
	Step	ON Setpoint	OFF Setpoint	Time Delay	Timer			Step Status
	1	13) 28.0	14) 30.0	15) 60	16)	0	17)	Off
	2	18) 27.0	19) 28.0	20) 60	21)	0	22)	On
	3	23) 25.5	24) 26.9	25) 60	26)	0	27)	Off
	4	28) 0.0	29) 0.0	30) 60	31)	0	32)	Off
	5	31) 0.0	34) 0.0	35) 0	36)	0	37)	Off
	6	38) 0.0	39) 0.0	40) 0	41)	0	42)	Off

Step	----- Pump Control Assignments -----									
1	43) HBP1	44)	45)	46)	47)					
	48)	49)	50)	51)	52)					
2	53) HBP1	54) HBP2	55)	56)	57)					
	58)	59)	60)	61)	62)					
3	63)	64) HBP2	65) HBP3	66)	67)					
	68)	69)	70)	71)	72)					
4	73)	74)	75)	76)	77)					
	78)	79)	80)	81)	82)					
5	83)	84)	85)	86)	87)					
	88)	89)	90)	91)	92)					
6	93)	94)	95)	96)	97)					
	98)	99)	100)	101)	102)					

103) Alternate Option : Yes

	Pump Id	alternate with	Pump Id
104)	HBP1	105)	HBP2
106)		107)	



Thursday July 23, 1987

1) Point Id : TMPC  
 2) Description : TRANS MAIN PUMP CONTROL  
 3) Mult. Step Control : Enable  
 4) Control Direction : Falling  
 5) Num Control Levels : 1 (0 Disables Control)  
     Control Level      Point Id      Current Value  
     1                    6) TTRSVL        7) 10.9  
     2                    8)                9) 0  
     3                    10)              11) 0

12) Number	OF Steps	Step	ON Setpoint	OFF Setpoint	Time Delay	Timer	Step Status
1	13)	10.2	14)	11.4	15)	20	16) 0 17) On
2	18)	9.0	19)	10.2	20)	20	21) 0 22) Off
3	23)	0.0	24)	0.0	25)	0	26) 0 27) Off
4	28)	0.0	29)	0.0	30)	0	31) 0 32) Off
5	31)	0.0	34)	0.0	35)	0	36) 0 37) Off
6	38)	0.0	39)	0.0	40)	0	41) 0 42) Off

Step	Pump Control Assignments					
1	43) TMP2	44)	45)	46)	47)	
	48)	49)	50)	51)	52)	
2	53) TMP1	54)	55)	56)	57)	
	58)	59)	60)	61)	62)	
3	63)	64)	65)	66)	67)	
	68)	69)	70)	71)	72)	
4	73)	74)	75)	76)	77)	
	78)	79)	80)	81)	82)	
5	83)	84)	85)	86)	87)	
	88)	89)	90)	91)	92)	
6	93)	94)	95)	96)	97)	
	98)	99)	100)	101)	102)	

103) Alternate Option : Yes      Pump Id      alternate with      Pump Id  
 104) TMP1                              105) TMP2  
 106)                                      107)



07/23/87 15:44:01

HEAVY TANK LEVELS


Page 1 of 1

Thursday

July 23, 1987

PPETLVL  
BMETLVL  
MPETLVL

HOLCOMB BLVD ETLVL



25.0

Print Cnst  Print  Rep Const Select Test < ESC > =====>



# Memorandum


DATE: 6 October 1986

FROM: Water Treatment Operator Foreman


TO: All Operators

SUBJ: FLUSHING EYEWASH STATIONS

1. All eyewash stations will be flushed for 3 minutes weekly on Thursdays. This flushing test will be logged on plant logsheet. A call will be made to Water Treatment Plant Operator Leader after flushing completed, acknowledging same.
2. Those water treatment plants without eyewashes piped with drains or without drains located nearby will use hoses and buckets until drain connection can be made.



B. M. FRAZELLE, II



# Memorandum


5100  
MAIN

DATE: 2 Oct 86  
FROM: Director, Utilities Branch  
TO: All Supervisors

SUBJ: FLUSHING OF EYEWASH STATIONS


Encl: (1) COMNAVMEDCOM Washington DC msg 041920Z Sep 86

1. Request that a program be started to comply with the enclosure. The requirement is to flush eyewash stations for at least three minutes once a week. Some method of documentation should be maintained (such as a log book) so that Base Safety can verify compliance. Since the water expended during this test will be considerable, provisions should be made for runoff to prevent unnecessary falls from stepping in puddling water. For example, those stations which are located adjacent to outside walls could be piped to the outside. Otherwise, stations will have to be piped to existing floor drains. Tickets should be requested for needed assistance.
2. Please inform this office upon completion. If any assistance is needed, please let me know.
3. Also, ensure that the program is described in your SOP's.


  
G. S. JOHNSON, JR.

DISTRIBUTION:


K. Shepard  
B. Meadows  
J. V. Jones  
M. Humphrey  
W. Price  
M. Frazelle  
M. Davis ✓  
J. Lisiewski  
G. Smith
























# Memorandum

5100  
MAIN

DATE: SEP 03 1986

FROM: Base Maintenance Officer

TO: Distribution List

SUBJ: POTENTIAL FIRE HAZARD

Ref: (a) LANTNAVFACENGCOC msg 251902Z

1. Per the reference, a potential fire hazard exists when disinfectant (pine oil), detergent, general purpose, NSN 6840-00-687-7904 manufactured by Lighthouse for the Blind is used on hot surfaces. The product contains terpene alcohols, oil fatty acids, anhydrous soap and has a flashpoint of 190 degree fahrenheit.

2. Users of the product should be advised that when it is used on hot surfaces it will ignite and burn easily. Extreme care should be exercised and the potential of a fire hazard should be avoided. There are no warnings listed on containers. Wide dissemination to any known user is requested.

*S. L. Marsicano*  
S. L. MARSICANO  
By direction


DISTRIBUTION: A

*Leadus*  
*Notify All Plants*

*Initial*

*A.P.*  
*T.T.*  
*M.P.*  
*MCAS*  
*RR*  
*C.H.B.*

*M*



*H.B.*  
*POST ON B.B.*

# Memorandum


DATE: 9 January 1985

FROM: Water Treatment Operator Foreman

TO: All Water Treatment Personnel

SUBJ: Use of Gas Mask, Policy, Re-iteration of

1. The Utility Director has expressed concern that some personnel are not using gas masks while changing chlorine, checking for chlorine leaks, etc. as required by Stand Operating Procedures.
2. Gas masks are not being maintained in a clean and working condition.
3. Commencing immediately, any personnel found changing chlorine or attempting to change chlorine or securing chlorine leaks or in chlorine room while chlorine is leaking with out a gas mask and/or in operating condition will be given disciplinary action.
4. Gas masks will be maintained in a clean and operable condition. This can be accomplished by washing with mild soap and warm water, wipe dry and reinstall in gas mask protective container. If oxygen supply is below 50%, contact leader for refill.
5. All personnel should be familiar with the operation of gas masks available. If any personnel are not, contact me immediately for operational procedures.

  
B. M. FRAZELLE, II

6 d  
26  
42



UNITED STATES MARINE CORPS  
Base Maintenance Division  
Marine Corps Base  
Camp Lejeune, North Carolina 28542

*Foreman Shop 83*

IN REPLY REFER TO  
MAIN/RES/jik  
5100/431  
OCT 19 1983


From: Base Maintenance Officer  
To: All Supervisors

Subj: Personnel Protective Equipment; non-utilization of

Ref: (a) MO 5100.1B

1. It is being brought to my attention that personnel protective equipment is not being utilized by employees when engaged in work requiring its use. In several instances this has resulted in lost time injuries at considerable expense to the government.
2. It is my intention to enforce the Base Maintenance policy set forth in the reference and as supervisors, I recommend you ensure compliance with both your responsibilities and the safety standards outlined in the order.
3. Effective immediately appropriate disciplinary action will be recommended for any employee or supervisor when there is an apparent disregard of either the compliance or enforcement of safety practices or procedures.

*J. T. Marshall*  
J. T. MARSHALL





*Bldg 670*

**UNITED STATES MARINE CORPS**  
Marine Corps Base  
Camp Lejeune, North Carolina 28542-5001

MO 6260.1  
MAIN/rsm  
21 Oct 85

MAINTENANCE ORDER 6260.1

From: Base Maintenance Officer  
To: Distribution List

Subj: Standing Operating Procedures for Respiratory Protection

Ref: (a) BO 6260.5

Encl: (1) Respiratory Protection Selection Guide

1. Purpose. To establish procedures for the selection and use of respirators in accordance with the reference.

2. Responsibilities

a. Supervisor Responsibility

(1) Respirators shall be provided by Base Maintenance when such equipment is necessary to protect the health of the employee.

(2) Base Maintenance shall provide the respirators which are applicable and suitable for the purpose intended.

(3) Supervisory personnel shall periodically monitor the use of respirators to ensure that they are worn properly.

(4) Supervisory personnel shall ensure that maintenance of respirators are carried out to ensure that each respirator wearer is provided with a respirator that is clean and in good operating condition. Maintenance shall include:

(a) Washing, sanitizing, rinsing and drying.

(b) Inspection for defects of respirators.

(c) Replacement of worn or deteriorated parts.

(d) Repair, if necessary.

(e) Storage to protect against dust, sunlight, excessive heat, extreme cold, excessive moisture, damaging chemicals and physical damage.

(5) Supervisory personnel will instruct employees thoroughly in the safe practices applicable to the operations performed and enforce the observance of all respiratory regulations.

(6) Supervisors will ensure personnel receive annual respirator training and physical examinations.

(7) Supervisors will ensure that respirator facepieces of more than one size shall be available to provide a proper fit.

(8) Supervisors will receive adequate training by Base Safety to ensure the proper use of respirators.

(9) Supervisors will ensure that employees receive pre-placement and annual physical examinations to determine their ability to perform assigned duties with respiratory protection.

(10) Supervisors should maintain a record of inspection dates and findings for respirators maintained for emergency use.

### 3. Employee Responsibility

(1) The employee shall use the provided respiratory protection in accordance with instructions and training received from Base Safety and supervisors.

(2) The employee shall guard against damage to the respirator.

(3) The employee shall report any malfunction of the respirator to the supervisor immediately.

(4) The employee will be required to check the seal of the respirator prior to entering a harmful atmosphere.

(5) Employees with facial hair that comes between the sealing periphery of the facepiece or interferes with valve function will not be permitted to wear a respirator. The absence of one of both dentures can seriously affect the fit of a facepiece.

(6) Employees using a respirator equipped with a full facepiece, helmet, hood or suit will not be allowed to wear contact lens. A proper seal cannot be established if the temple bars of eyeglasses extend through the sealing edge of the full facepiece. If corrective spectacles are required, they will be worn so as not to affect the fit of the facepiece.

3. Training. Each respirator wearer will be given training which shall include explanation and discussion of:

- a. The respiratory hazard if the respirator is not used properly.
- b. The need for respirators to provide protection.
- c. The reason for selecting a particular type of respirator.
- d. The function, capabilities and limitations of the selected respirator.
- e. The proper wearing of the respirator.
- f. The method of donning the respirator and checking its fit and operation.
- h. Respirator maintenance.
- i. Recognizing and handling emergency situations.

Each respirator wearer shall be retrained at least annually.

4. Selection of Respirator. The selection of a proper respirator for any given situation shall require consideration of the following factors:

- a. The nature of the hazard.
- b. The characteristics of the hazardous operation or process.
- c. The location of the hazardous area with respect to a safe area having respirable air.
- d. The period of time for which respiratory protection may be provided.
- e. The activity of workers in the hazardous area.
- f. The physical characteristics, functional capabilities and limitations of respirators of various types.
- g. The respirator-protection factors and respiratory fit.

RESPIRATORY PROTECTION SELECTION GUIDE


JOB/MATERIAL	CARTRIDGE COLOR CODE	APPROVED RESPIRATOR	NSN
ORGANIC VAPORS SOLVENTS, PAINTS DEGREASERS, THINNERS DRY CLEANING SOLVENT PD 680 CLEANING PAINT BRUSHES BRUSH OR SPRAY PAINTING SPRAY CAN PAINTING FUEL VAPORS ENAMEL AND ACRYLIC PAINTS	BLACK	DISPOSABLE 3M #8741 ORGANIC VAPOR/SPRAY PAINT ASSEMBLY WITH PRE-FILTERS *  DISPOSABLE NORTON #10041M ORGANIC VAPOR MASK WITH PRE-FILTERS *  DISPOSABLE ORGANIC VAPOR RESPIRATOR 3M #8712 WITHOUT PRE-FILTERS	4240-01-131-9722       4240-01-074-8930
GRINDING/CHIPPING FLAP BRUSHING FIBERGLASS WORK WOOD SANDING, COAL DUST SAW DUST NUISANCE DUSTS ASBESTOS - LOW LEVELS METAL DUSTS (LEAD) ASBESTOS - HIGH LEVELS (RIP-OUT)	GRAY TOP CARTRIDGE  WHITE PAPER	DUST/MIST/FUME DUAL FILTER (CARTRIDGE MASK)  DISPOSABLE DUST MASK 3M #8710  DISPOSABLE DUST/MIST MASK 3M #9910  FULL FACEPIECE SUPPLIED AIR RESPIRATOR	4240-00-099-6939  4240-00-629-8199  4240-01-081-6433  4240-00-275-3178
WELDING - METAL FUMES BRAZING SOLDERING CUTTING METALS	PAPER  GRAY TOP CARTRIDGE	DUST/MIST/FUME DUAL FILTER (CARTRIDGE MASK)  DISPOSABLE 3M #9920 DUST/MIST/FUME MASK	4240-00-099-6939  4240-01-108-4171
BERYLLIUM METAL DUST TICONIUM PROSTHETICS S-3/F-14 BRAKE PARTS CADMIUM DUST	MAGENTA (PURPLE)	HEPA CARTRIDGE TYPE  DISPOSABLE 3M #9940 DISPOSABLE NORTON #10030M	OPEN PURCHASE  OPEN PURCHASE
PESTICIDES	BLACK CART- RIDGE WITH PRE-FILTER	PESTICIDE CARTRIDGE TYPE  DISPOSABLE 3M #8751 DISPOSABLE NORTON #10041M	4240-01-035-9250 OPEN PURCHASE
CONFINED SPACE ENTRY & STAND BY, OXYGEN DEFICIENCY ATMOSPHERE		SELF-CONTAINED BREATHING APPARTUS	OPEN PURCHASE
BATTERY CHARGING ACID MISTS ACID CLEANING	WHITE YELLOW**	ACID-GAS CARTRIDGE TYPE DISPOSABLE 3M #8714 DISPOSABLE NORTON #10002M	OPEN PURCHASE

\* PRE-FILTERS ONLY REQUIRED FOR SPRAY PAINTING OPERATIONS

\*\* ORGANIC VAPOR-ACID GAS COMBINATION CARTRIDGE

NOTE: ITEMS PROVIDE MINIMUM PROTECTION FOR AIR CONTAMINATE LISTED. CONSULT LOCAL INDUSTRIAL HYGIENIST FOR ASSISTANCE IN SELECTION IF NEEDED. USE OF DISPOSABLES HIGHLY RECOMMENDED TO SAVE ON CLEANING, MAINTENANCE AND SPARE PARTS COSTS AND MANHOURS. DISPOSABLES USUALLY FOUND MORE COST EFFECTIVE THAN DUAL CARTRIDGE TYPE REPLACEABLE CARTRIDGE RESPIRATORS.


ENCLOSURE (1)



Enclosure (1) provides examples of respirators designed for specific applications. The Commanding Officer, Naval Hospital in conjunction with Base Safety will recommend respiratory protection equipment for personnel, based upon the nature and degree of the hazard involved, in accordance with current National Institute for Occupational Safety and Health/Mine Safety and Health Administration (NIOSH/MSHA) approval/certification.


5. Confined Spaces. All confined spaces shall be considered to be immediately dangerous to life or health unless proven otherwise. Before a person is allowed to enter a confined space, tests will be conducted by the cognizant Industrial Hygienist or the Base Gas Free Engineer to determine the concentration of any known or expected flammable or toxic contaminant present. A person will not be allowed to enter a confined space without wearing the proper type of respirator. A standby person shall be present in a safe area with proper equipment, available to assist the respirator wearer in case of an emergency.

6. Applicability. Effective upon receipt, Branch and Section heads, supervisors, foremen and maintenance personnel will ensure compliance with these procedures within their area of responsibility.

  
W. M. RICE

DISTRIBUTION: A

Copy to: Ea Bulletin Board



# Memorandum

DATE: 7 November 1985

FROM: Utilities Systems General Foreman

TO: All Water and Wastewater Plant Employees

SUBJ: MO 6260.1

1. Effective immediately, MO 6260.1, dtd 21 October 1985, shall be adhered to by all personnel.

*W. R. Price*  
W. R. PRICE





UNITED STATES MARINE CORPS  
Marine Corps Base  
Camp Lejeune, North Carolina 28542-5001

MO 6260.1  
MAIN/rsm  
21 Oct 85

H.D.

MAINTENANCE ORDER 6260.1

From: Base Maintenance Officer  
To: Distribution List

Subj: Standing Operating Procedures for Respiratory Protection

Ref: (a) BO 6260.5

Encl: (1) Respiratory Protection Selection Guide

1. Purpose. To establish procedures for the selection and use of respirators in accordance with the reference.

2. Responsibilities

a. Supervisor Responsibility

(1) Respirators shall be provided by Base Maintenance when such equipment is necessary to protect the health of the employee.

(2) Base Maintenance shall provide the respirators which are applicable and suitable for the purpose intended.

(3) Supervisory personnel shall periodically monitor the use of respirators to ensure that they are worn properly.

(4) Supervisory personnel shall ensure that maintenance of respirators are carried out to ensure that each respirator wearer is provided with a respirator that is clean and in good operating condition. Maintenance shall include:

(a) Washing, sanitizing, rinsing and drying.

(b) Inspection for defects of respirators.

(c) Replacement of worn or deteriorated parts.

(d) Repair, if necessary.

(e) Storage to protect against dust, sunlight, excessive heat, extreme cold, excessive moisture, damaging chemicals and physical damage.

(5) Supervisory personnel will instruct employees thoroughly in the safe practices applicable to the operations performed and enforce the observance of all respiratory regulations.

(6) Supervisors will ensure personnel receive annual respirator training and physical examinations.

(7) Supervisors will ensure that respirator facepieces of more than one size shall be available to provide a proper fit.

(8) Supervisors will receive adequate training by Base Safety to ensure the proper use of respirators.

(9) Supervisors will ensure that employees receive pre-placement and annual physical examinations to determine their ability to perform assigned duties with respiratory protection.

(10) Supervisors should maintain a record of inspection dates and findings for respirators maintained for emergency use.

### 3. Employee Responsibility

(1) The employee shall use the provided respiratory protection in accordance with instructions and training received from Base Safety and supervisors.

(2) The employee shall guard against damage to the respirator.

(3) The employee shall report any malfunction of the respirator to the supervisor immediately.

(4) The employee will be required to check the seal of the respirator prior to entering a harmful atmosphere.

(5) Employees with facial hair that comes between the sealing periphery of the facepiece or interferes with valve function will not be permitted to wear a respirator. The absence of one of both dentures can seriously affect the fit of a facepiece.

(6) Employees using a respirator equipped with a full facepiece, helmet, hood or suit will not be allowed to wear contact lens. A proper seal cannot be established if the temple bars of eyeglasses extend through the sealing edge of the full facepiece. If corrective spectacles are required, they will be worn so as not to affect the fit of the facepiece.

3. Training. Each respirator wearer will be given training which shall include explanation and discussion of:

- a. The respiratory hazard if the respirator is not used properly.
- b. The need for respirators to provide protection.
- c. The reason for selecting a particular type of respirator.
- d. The function, capabilities and limitations of the selected respirator.
- e. The proper wearing of the respirator.
- f. The method of donning the respirator and checking its fit and operation.
- h. Respirator maintenance.
- i. Recognizing and handling emergency situations.

Each respirator wearer shall be retrained at least annually.

4. Selection of Respirator. The selection of a proper respirator for any given situation shall require consideration of the following factors:

- a. The nature of the hazard.
- b. The characteristics of the hazardous operation or process.
- c. The location of the hazardous area with respect to a safe area having respirable air.
- d. The period of time for which respiratory protection may be provided.
- e. The activity of workers in the hazardous area.
- f. The physical characteristics, functional capabilities and limitations of respirators of various types.
- g. The respirator-protection factors and respiratory fit.

RESPIRATORY PROTECTION SELECTION GUIDE


JOB/MATERIAL	CARTRIDGE COLOR CODE	APPROVED RESPIRATOR	NSN
ORGANIC VAPORS SOLVENTS, PAINTS DEGREASERS, THINNERS DRY CLEANING SOLVENT PD 680 CLEANING PAINT BRUSHES BRUSH OR SPRAY PAINTING SPRAY CAN PAINTING FUEL VAPORS ENAMEL AND ACRYLIC PAINTS	BLACK	DISPOSABLE 3M #8741 ORGANIC VAPOR/SPRAY PAINT ASSEMBLY WITH PRE-FILTERS *  DISPOSABLE NORTON #10041M ORGANIC VAPOR MASK WITH PRE-FILTERS *  DISPOSABLE ORGANIC VAPOR RESPIRATOR 3M #8712 WITHOUT PRE-FILTERS	4240-01-131-9722      4240-01-074-8930
GRINDING/CHIPPING FLAP BRUSHING FIBERGLASS WORK WOOD SANDING, COAL DUST SAW DUST NUISANCE DUSTS ASBESTOS - LOW LEVELS METAL DUSTS (LEAD) ASBESTOS - HIGH LEVELS (RIP-OUT)	GRAY TOP CARTRIDGE  WHITE PAPER	DUST/MIST/FUME DUAL FILTER (CARTRIDGE MASK)  DISPOSABLE DUST MASK 3M #8710  DISPOSABLE DUST/MIST MASK 3M #9910  FULL FACEPIECE SUPPLIED AIR RESPIRATOR	4240-00-099-6939  4240-00-629-8199  4240-01-081-6433  4240-00-275-3178
WELDING - METAL FUMES BRAZING SOLDERING CUTTING METALS	PAPER  GRAY TOP CARTRIDGE	DUST/MIST/FUME DUAL FILTER (CARTRIDGE MASK)  DISPOSABLE 3M #9920 DUST/MIST/FUME MASK	4240-00-099-6939  4240-01-108-4171
BERYLLIUM METAL DUST TICONIUM PROSTHETICS S-3/F-14 BRAKE PARTS CADMIUM DUST	MAGENTA (PURPLE)	HEPA CARTRIDGE TYPE  DISPOSABLE 3M #9940 DISPOSABLE NORTON #10030M	OPEN PURCHASE  OPEN PURCHASE
PESTICIDES	BLACK CART- RIDGE WITH PRE-FILTER	PESTICIDE CARTRIDGE TYPE  DISPOSABLE 3M #8751 DISPOSABLE NORTON #10041M	4240-01-035-9250 OPEN PURCHASE
CONFINED SPACE ENTRY & STAND BY, OXYGEN DEFICIENCY ATMOSPHERE		SELF-CONTAINED BREATHING APPATUS	OPEN PURCHASE
BATTERY CHARGING ACID MISTS ACID CLEANING	WHITE YELLOW**	ACID-GAS CARTRIDGE TYPE DISPOSABLE 3M #8714 DISPOSABLE NORTON #10002M	OPEN PURCHASE

\* PRE-FILTERS ONLY REQUIRED FOR SPRAY PAINTING OPERATIONS

\*\* ORGANIC VAPOR-ACID GAS COMBINATION CARTRIDGE

NOTE: ITEMS PROVIDE MINIMUM PROTECTION FOR AIR CONTAMINATE LISTED. CONSULT LOCAL INDUSTRIAL HYGIENIST FOR ASSISTANCE IN SELECTION IF NEEDED. USE OF DISPOSABLES HIGHLY RECOMMENDED TO SAVE ON CLEANING, MAINTENANCE AND SPARE PARTS COSTS AND MANHOURS. DISPOSABLES USUALLY FOUND MORE COST EFFECTIVE THAN DUAL CARTRIDGE TYPE REPLACEABLE CARTRIDGE RESPIRATORS.


ENCLOSURE (1)



Enclosure (1) provides examples of respirators designed for specific applications. The Commanding Officer, Naval Hospital in conjunction with Base Safety will recommend respiratory protection equipment for personnel, based upon the nature and degree of the hazard involved, in accordance with current National Institute for Occupational Safety and Health/Mine Safety and Health Administration (NIOSH/MSHA) approval/certification.

5. Confined Spaces. All confined spaces shall be considered to be immediately dangerous to life or health unless proven otherwise. Before a person is allowed to enter a confined space, tests will be conducted by the cognizant Industrial Hygienist or the Base Gas Free Engineer to determine the concentration of any known or expected flammable or toxic contaminant present. A person will not be allowed to enter a confined space without wearing the proper type of respirator. A standby person shall be present in a safe area with proper equipment, available to assist the respirator wearer in case of an emergency.

6. Applicability. Effective upon receipt, Branch and Section heads, supervisors, foremen and maintenance personnel will ensure compliance with these procedures within their area of responsibility.

  
W. M. RICE

DISTRIBUTION: A

Copy to: Ea Bulletin Board



# Memorandum

DATE: 24 September 1985


FROM: Foreman, Water Treatment

TO: All Water Treatment Plant Personnel

SUBJ: Chlorine Gas Mask; use of

1. New Wilson respirators have been issued to all water treatment plants replacing the old canister types. The respirators will be used when changing chlorine cylinders and will be on the employee's face in working order whenever chlorine is changed.
2. If while changing chlorine a leak develops or any other time a leak in chlorine is detected the self contained breathing apparatus (Scott or Survivair) will be utilized to shut off chlorine, repair, etc.
3. These directives are for your protection. The new Wilson respirator is only good up to 10 p.p.m. chlorine and will not sustain life in a heavily concentrated chlorine environment. When a leak develops there is no way to determine what concentration chlorine is present so it is imperative that you wear the self contained breathing apparatus.
4. The Wilson respirator will only be used for changing chlorine. These directives will be strictly adhered to.

  
BYRON M. FRAZELLE



670

DATE: 18 May 1984


FROM: Water Plant Operator Foreman

TO: All Water Treatment Personnel

SUBJ: Unloading of bulk supplies; receipts for

1. Problems are still arising with the unloading of chemical bulk supplies such as lime, and salt. Truck drivers are informing operators and other personnel that the weigh station is closed; that they are not getting weight certificates from the weigh station, etc.
2. Commencing immediately you will not unload a truck of salt or lime unless you have in your possession a weight certificate from the weigh station located aboard Camp Lejeune. The certificate is titled "WEIGHT CERTIFICATE (MCBCL 4600/2)".
3. This WEIGHT CERTIFICATE (Copy) will be sent to Bldg. 670 as soon as possible for record keeping.
4. If the truck driver does not have a weight certificate as listed above, YOU WILL NOT LET HIM UNLOAD. You will inform the driver of this and ask him to wait. You will then call 5988, 1081 or 2069 and inform the Leader of the situation. The Leader will then call the weigh station, Phone No. 1778 giving the weigh master the truck number that is trying to unload and ascertain if in fact he has weighed in. The Leader will then call you back and tell you if it is all right to unload the truck. The Leader will then log in the appropriate information in the Check-in book located on the desk at Bldg. 670.
5. Personnel will then log in all information on Plant Log Sheets; this includes truck number, time in and time out, and date and material received.
6. This has become necessary to preclude paying for bulk supplies we do not receive. Since all personnel have been notified of this before, disciplinary action may be recommended for failure to carry out these instructions.

  
B. M. FRAZELLE II



**BASE MAINTENANCE DIVISION**  
Marine Corps Base  
Camp Lejeune, North Carolina 28542

MAIN/BMF/spk  
5000  
9 May 1983

From: Water Treatment Plant Operator Foreman  
To: Water Treatment Plant Leaders

Subj: Clarification of Duties of Water Treatment Plant Operator Leaders


1. Since the Water Treatment Plant Operator Leader positions have been established and personnel assigned to shifts, many questions have arisen concerning their duties, responsibilities and authority. The following information is provided to clarify these questions.

2. The Leaders are tasked with the responsibility of the smooth operation of the water treatment facilities. They have basically the same responsibility and authority that I have with the exception, they cannot grant leave, give disciplinary action (but can recommend), and fill out performance appraisals. This authority does not eliminate each individual operator from his responsibility of operating each plant, correcting problems, and notifying the leaders of problems arising, etc.

LEADERS RESPONSIBILITY AND AUTHORITY INCLUDE, BUT IS NOT LIMITED TO, THE FOLLOWING:


- A. Passing on to others the instructions received from supervisors, getting work started, assigning tasks to be performed, etc.
- B. Seeing to it that needed supplies are provided.
- C. Obtaining needed information from supervisors on problems that come up during the work period.
- D. Maintains current knowledge and answers questions of other workers on procedures, policies, written instructions, and other directives.
- E. Sees to it that there is enough work to keep everyone busy.
- F. Checks work in progress to see whether the supervisors' instructions procedures, methods, and deadlines are met.
- G. Assures safety and housekeeping rules are followed.
- H. Reports to Supervisor on status of work, progress, and causes of work delays.

3. Leaders then basically have the same authority that I have with the exception of those outlined in paragraph 2 above. Each employee should abide by the information and directions given them by the Leader on duty.



4. In my opinion the water treatment branch has the best group of people employed on Camp Lejeune. Let each of us strive to be as industrious and efficient as we can and continue to have the best working environment aboard the Base. If problems arise, please notify me immediately.

*Byron M. Frazelle, II*  
BYRON M. FRAZELLE, II





UNITED STATES MARINE CORPS  
Base Maintenance Division  
Marine Corps Base  
Camp Lejeune, North Carolina 28542

IN REPLY REFER TO  
5100  
MAIN  
7 AUG 1984

MEMORANDUM

From: Base Maintenance Officer  
To: Distribution List  
Subj: CONFINED SPACE ENTRY PROGRAM

Ref: (a) Training Session held 2 Aug 84

1. As a result of the reference, and pending publication of a base order on the Confined Space Entry Program, the following guidelines are issued:

a. The Gas Free Engineer will be notified and appropriate clearance received for:

- (1) All work in confined spaces which will involve "hot work."
- (2) All work in confined spaces which will require prolonged or extensive repairs or replacement of parts.
- (3) Any situation involving work or entry into a confined space in which the safety of employees is questionable.

b. After duty hours/weekends, the night foreman/duty NCO will call the Gas Free Engineer (Mr. Tex Ritter, telephone 329-3701) prior to initiating any work noted in paragraph 1a above. In the event the Gas Free Engineer cannot be reached, the Fire Department will be called.

2. Equipment requirements will be forwarded to the Assistant Base Maintenance Officer not later than 15 August 1984.

*F. E. Cone*  
F. E. CONE  
By direction

Distribution: A  
Base Safety Manager




670, Leachman

# Memorandum

DATE: 31 December 1985  
FROM: Foreman, Water Treatment  
TO: All Personnel, Courthouse Bay Water Treatment Plant  
SUBJ: ONSLOW BEACH BACKWASH HOLDING POND

1. The analysis of the Suspended Solids test in October for subject pond indicated it was 95. This is a violation of NPDES Permit and has to be reported by the Commanding General, MCB to the State of N.C. The reason the pond violated the NPDES permit is because it was pumped to low.
2. Henceforth the following will be strictly adhered to:
  - a. The backwash pond does not have to be pumped weekly. The only time a Suspended Solids test is needed is when the pump is on, i.e. whenever you are lowering the water level in the pond or any other time you are running the pump.
  - b. Do not pump pond level down unless the water level in the pond is at least 2 feet from the top of the pump station located in the backwash pond.
  - c. A p.H. sample is not needed weekly on the pond. You only need to collect a p.H. sample when the pump on the pond is on.
3. To repeat: Only pump the pond when the water level is 2 feet from the top of the pump station. Do not collect any sample unless pond is being pumped. Continue to try to pump pond on Tuesday when the pond needs pumping. The pond can be pumped on other days in the week but remember whenever you are pumping make sure a p.H. sample and a SS sample are collected and turned into the Lab for analysis.
4. If there are any questions concerning the above call me at once.

  
MACK FRAZELLE



MERCURY SPILL  
STANDING OPERATING PROCEDURES

Subject: Standing Operating Procedure - Mercury Spill Cleanup  
Purpose: To publish a standard procedure for the cleanup of mercury spills.

1. Responsibility:

a. The Industrial Hygiene Section is responsible for:

(1) Monitoring the contaminated site before and after cleanup.

(2) Making recommendations for cleanup.

(3) Recommending use of protective equipment for area control and personal control measures.

(4) Providing an industrial mercury vacuum for large spills contact Industrial Hygiene, extension 2707.

b. The Chemist, Utilities Branch is responsible for:

(1) Ensuring that proper equipment and protective equipment is provided for Steam, Water and Wastewater Sections.

(2) Ensuring that proper cleanup equipment and protective equipment is utilized by cleanup personnel.

(3) Coordinating the disposal of mercury obtained from spill with Defense Reutilization Marketing Officer (DRMO) representatives.

c. Instrument Mechanics from steam, water and wastewater are responsible for cleaning up mercury spills in their sections.


2. General:

a. The area in which the spill occurs should be isolated (roped off) until cleanup is completed and monitoring indicates safe exposure levels.

b. Contact will be made with the Industrial Hygiene Section, as soon as possible, whenever a spill occurs at extension 2707. Industrial Hygiene hours 0800-1600, Monday through Friday.

c. Mercury spill will be cleaned up by an Instrument Mechanic from the section involved. If spill is considered to be major, Industrial Hygiene Section will assist with cleanup.

d. Mercury will be disposed of according to guidelines set forth by the DRMO representatives, by the Utilities Chemist.



SOP for Mercury Spills cont'd

3. Cleanup and Safety Equipment

a. Mercury spill Cleanup Kit including:

- (1) Butyl or latex gloves
- (2) Safety goggles
- (3) Tyvek suit with shoe covers
- (4) Suction device or aspirator fitted with mercury trap
- (5) Scoop bottles
- (6) Plastic bags with ties and labels

b. Respirator for confined area spills:

- (1) Positive pressure self contained breathing apparatus
- (2) Positive pressure supplied air respirator
- (3) Mercury vapor respirator filters (3M Company)

c. Mercury Decontaminant

d. Industrial mercury vacuum cleaner for major spills. This can be obtained from Industrial Hygiene Section, extension 2707.

4. Cleanup Procedure:

a. The area in which the spill occurs should be isolated (roped off) as soon as possible.

b. The spill should be reported to the Industrial Hygiene Section, extension 2707, as soon as possible so monitoring and cleanup procedures can be implemented. Industrial Hygiene's hours are 0800 to 1600, Monday through Friday.

c. All personnel should be cleared from the immediate spill area except for those involved in the cleanup. No smoking, eating, or drinking is allowed in the spill area. Cleanup personnel should wear self contained breathing apparatus or other approved respirator. The choice of respirator will be dependent upon concentration of vapor.

d. Protective gloves, goggles, and clothing should be worn. Tyvek coveralls are satisfactory as whole body protection.

e. No sweeping or blowing of mercury is permitted; gather up as many globules as possible by vacuuming. Globules caught in cracks or recesses may be collected with a suction device fitted with a mercury trap. A magnifying glass will be useful in locating minute globules. A scoop can be used to pick up all but the smallest globules. Scoops which can not be decontaminated should be disposed of as a hazardous waste.

f. After all visible globules have been picked up, cover




SOP for Mercury Spills (cont'd)

the spill surfaces with generous quantities of melted decontaminant mixture to convert mercury not removed by the previous techniques. Leave the decontaminant mixture on the surface overnight to obtain maximum conversion of mercury. The mixture should be worked into cracks and crevices. Vertical surfaces such as walls, cabinet sides, and furniture legs should be checked for mercury.

g. After the mercury concentration has fallen to a safe level, not greater than  $0.05 \text{ mg/m}^3$ , the spill area should be scrubbed with soap and water and rinsed.


h. Sensible personal hygiene practices during and after clean-up are important. Since mercury can be absorbed through the skin, care should be taken not to handle contaminated components directly. Exposed skin should be thoroughly washed with soap and water. Contaminated clothing should be placed in double plastic bags for later monitoring and disposal.





EMERGENCY PHONE NUMBERS

Earl Haley	Superintendent	
John Muter	Field Engineer	455-1393
Phil Reese	C.Q.C. Officer	1-298-4416
Randy McDonald	Field Supervisor	1-327-2785
Clyde Jenkins	Mechanical Supervisor	347-4338
Ken Cruikshank	Labor Foreman	346-2910



670

# Memorandum


DATE: 26 September 1986


FROM: Water Treatment Operator Foreman

TO: All Water Treatment Plant Leaders

SUBJ: HAULING CATALYST; ACTION REQUIRED

1. Commencing 1 October 1986, a ticket will have to be called in for each plant catalyst is being hauled from.
2. In order for Roads and Grounds to plan catalyst hauling, leaders will have to ascertain the amount of catalyst to be hauled. Leaders will call lime softening plants on Fridays and Wednesdays and relay information to Sally for the number of loads of catalyst to be hauled. Sally will turn in tickets accordingly.
3. Tickets will also be needed for sand hauling and days we change all catalyst in spiractors. If Friday notice becomes too far in advance for actual catalyst needs, a change of hauling days may be required.

  
B. M. FRAZELLE, II



# Memorandum

DATE: 15 August 1986

FROM: Foreman, Water Treatment

TO: Director, Utilities

SUBJ: Operational Water Reports, Request For; information concerning

Ref: (a) Mr. F. Hill's ltr of 16 April 86 to CG, MCB, Camp Lejeune, N. C.


1. On 14 August 1986 a meeting was held between Mr. Fred Hill, Water Plant Consultant, N. C. Department of Human Resources and myself. The purpose of this meeting was to discuss the submission of Water Treatment Reports to the N. C. Department of Natural Resources as requested by the reference. Mr. Hill requested that the following information be sent to the Water Supply Branch, Division of Health Services, Raleigh, N. C. The report will include the below listed information; will be submitted per plant; and be submitted prior to the 10th day of the following month.


## DATA TO BE SUBMITTED

- a. Total Water Pumped in MGD, Daily
- b. Hours Plant Operated, Daily
- c. Backwash Water Used in Gallons, Daily
- d. Turbidity, p.p.m. (Only on Lime Softening Plants) Daily
- e. Chlorine Used in Lbs., Daily
- f. Lime Used in Lbs., Daily
- g. Phosphate Used in Lbs., Daily
- h. Fluoride Used in Lbs., Daily
- i. p.H. of Raw, and Finished Water, Daily
- j. Hardness of Raw, Treated and Delivered Water, p.p.m., Daily
- k. Alkalinity of Raw, Filtered and Delivered Water, p.p.m., Daily
- l. Free Chlorine Residual, Treated and Delivered Water, p.p.m. Daily
- m. Fluoride Residual, p.p.m. (Only on plants adding Fluoride), Daily

NOTE: THOSE READINGS TAKEN MORE THAN ONCE DAILY WILL REQUIRE AVERAGING FOR THIS REPORT. LIME, FLUORIDE MACHINE ON CONTINUOUS FEED WILL REQUIRE WEIGHING MATERIAL AND CALCULATED DATA SUBMITTED. THIS WILL ALSO REQUIRE WEIGHING MATERIAL EACH TIME FEEDER IS CUT UP OR DOWN AND LENGTH OF TIME RECORDED FOR EACH SETTING.

2. It should be noted that this report will require an extreme amount of manhours to prepare, maintain and submit.

  
B. M. FRAZZLE



BLDG. 670 - RUNNING AND SERVICE PROCEDURES FOR GENERATOR & GAS AUX MOTORS.

Generators and Gas auxiliary motors are to be run once a week on Thursdays UNDER A LOAD for at least 30 minutes or more.


Service generators and gas auxiliary motors by:

1. Check oil
2. Check water level in radiator
3. Check battery level
4. check gas AFTER use.

To run generator:

1. Crank generator - make sure it is putting right amount of volts out (480 volts). Let it run until it warms up.
2. Go to wall and pull transfer switch level from commercial to off and then to generator.
3. Go back to generator and throw switch underneath control panel to on.
4. Run generator for at least 30 minutes or more UNDER A LOAD.
5. To switch back to commercial power:
  - a. Throw switch underneath control panel to off.
  - b. Go back to transfer panel on wall, switch level to off, wait 2 minutes and put switch up to commercial.

Well men will run their auxiliary motors on Thursday and Fridays UNDER LOAD!



REMOTE DATA FAILS

WELL SITES

R 1	DF	643	We11	1	NEW we11	698
" 2	"	644	"	2	" "	699
3		<del>645</del>	ONSLow BEACH	3		700
4		646		4		701
5		647		5		703
6		648		6		704
7		649		7		705
8		650		8		706
9		NEW WELL	1 -698	9		707
10		" "	2 -699	10	NEW Well	708
11			3 -700	11	WELL 643	
12			4 -701	12	644	
13			5 -703	13	645	
14			6 -704	14	646	
15			7 -705	15	647	
16			8 -706	16	648	
17			9 -707	17	649	
18			10 -708	18	650	
19		TTET				
20		MFPET				
21		PPET				
22		BMET				
23		MPET				
24		TT PUMP STATION				